

MEP Equipment Schedule												
Project Title		Havant Justice Centre			Originator		LB	Revision		P01		AtkinsRéalisis
Document No.		5225905			Checker		TC	Revision Date		15/02/2024		
Description		Louvre Schedule			Approver		TC	Status		RIBA Stage 3		
General				Technical Information						Physical Data		Additional Notes
Reference	Associated System	Description (intake / discharge)	Location	Air Flow Rate	Face Velocity	Louvre Face Area Required	Max PD	Room Noise Level	Plenum	Dimensions		Comments
										Length	Width	
										(mm)	(mm)	
WL-00-01	MVHR-00-01	Intake	Wall	581	1.5	0.45		30		675	675	Size includes insect mesh.
WL-00-02	MVHR-00-01	Discharge	Wall	581	2	0.33		30		575	575	Size includes insect mesh.
WL-00-03	MVHR-00-02	Intake	Roof	639	1.5	0.49		30		700	700	Size includes insect mesh.
WL-00-04	MVHR-00-02	Discharge	Roof	639	2	0.37		30		600	600	Size includes insect mesh.
WL-00-05	MVHR-00-03	Intake	Wall	1309	1.5	1.00		30		1000	1000	Size includes insect mesh.
WL-00-06	MVHR-00-03	Discharge	Wall	1309	2	0.75		30		875	875	Size includes insect mesh.
WL-00-07	MVHR-00-04	Intake	Wall	314	1.5	0.24		30		500	500	Size includes insect mesh.
WL-00-08	MVHR-00-04	Discharge	Wall	314	2	0.18		30		425	425	Size includes insect mesh.
WL-00-09	MVHR-00-05	Intake	Wall	748	1.5	0.57		30		750	750	Size includes insect mesh.
WL-00-10	MVHR-00-05	Discharge	Wall	748	2	0.43		30		650	650	Size includes insect mesh.