



Department of Planning and Development
Havant Borough Council
Public Service Plaza
Civic Centre Road
Havant
Hampshire
PO9 2AX

Your ref
APP/24/00162

Our ref
DSA000032404

Date
28 March 2024

Contact
Tel 0330 303 0119

Dear Sir/Madam,

Proposal: Installation of 2No. prefabricated enclosed jet wash bays.

Site: APP/24/00162: - Petrol Filling Station, 97 Park Lane, Bedhampton, Havant, PO9 3HQ.

Thank you for your letter dated 11 March 2024.

Following the review of the submitted documents, we have the below comments for the Planning consultation.

Foul and Surface Water Drainage

Southern Water requires a formal application for a connection to the public foul sewer to be made by the applicant or developer.

To make an application visit Southern Water's Get Connected service: developerservices.southernwater.co.uk and please read our New Connections Charging Arrangements documents which are available on our website via the following link: southernwater.co.uk/developing-building/connection-charging-arrangements

The Council's technical staff and the relevant authority for land drainage should comment on the adequacy of the proposals to discharge surface water to the local watercourse.

We request that should this planning application receive planning approval, the following informative is attached to the consent: Construction of the development shall not commence until details of the proposed means of foul sewerage and surface water disposal have been submitted to, and approved in writing by the Local Planning Authority in consultation with Southern Water.

Trade Effluent

Areas used for vehicle washing should only be connected to the public foul sewer upon receipt of a trade effluent discharge license.

The Trade Effluent application process for non-household (NHH) customers has changed since April 2017. This was a government decision to open the Market to competition.

In order to apply for a consent, you will need to engage a Retailer and submit the application through them.

Southern Water (SWS) is still the owner of assets (Wholesaler), but all administrative or billing matters are conducted by the Retailer of your choice.

Attached is a link to the Open Water website that lists Retailers available. Please note that not all Retailers will provide a Trade Effluent service. open-water.org.uk/for-customers/find-a-retailer/suppliers/english-water-and-wastewater-retailers

Once we have received an application via your appointed water retailer, we have 2 months to issue a consent or refuse the application. Any requirement to discharge directly to the environment will require a permit/consent from the Environment Agency.

Should the Local Planning Authority be minded to grant planning permission for this development we request that the following condition is attached to the consent: The applicant should ensure that the Trade Effluent discharge license has been obtained, before the connection to the public sewerage network can be approved.

For further advice, please contact Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX (Tel: 0330 303 0119).

Website: southernwater.co.uk or by email at: SouthernWaterPlanning@southernwater.co.uk

Yours faithfully,

Future Growth Planning Team
Developer Services

southernwater.co.uk/developing-building/planning-your-development