

From: Le-Vallee, Helen <helen.le-vallee@easthants.gov.uk>

Sent: 26 August 2022 15:43

To: Pickup, Tina <Tina.Pickup@havant.gov.uk>

Subject: APP/22/00421 | Demolition of existing commercial building and erection of replacement commercial building. | Convenient Hire Ltd, Aston Road, Waterlooville, PO7 7RH

Thank you for consulting the Pollution Team on the above application. Please note these comments relate to noise and dust only.

We have no objections to the proposal however, we would welcome more information about any external plant which may be installed as part of the redevelopment, including air handling units etc., which may give rise to problems at nearby residential properties. Where external plant is to be installed then it is likely that a BS4142 noise assessment will be required. In terms of noise and dust from the demolition and construction we recommend a CEMP condition be attached in order to control hours/days of work, no bonfires, and measures for dust control.

Regards

Helen Le-Vallee
Environmental Health Officer
Direct Dial: 01730 234302



East Hampshire District Council
Penns Place, Petersfield
GU31 4EX

www.easthants.gov.uk
www.facebook.com/easthantsdc
www.twitter.com/easthantsdc

Your privacy matters, go to www.easthants.gov.uk/privacy-policy



Havant Borough Council
Public Service Plaza, Civic Centre
PO9 2AX

www.havant.gov.uk
www.facebook.com/havantborough
www.twitter.com/havantborough

Your privacy matters, go to www.havant.gov.uk/privacy-policy