



*Economy, Transport and Environment Department
Elizabeth II Court West, The Castle
Winchester, Hampshire SO23 8UD*

Tel: 0300 555 1375 (General Enquiries)
0300 555 1388 (Roads and Transport)
0300 555 1389 (Recycling Waste & Planning)
Textphone 0300 555 1390
Fax 01962 847055
www.hants.gov.uk

Enquiries to	Sarah Reghif	My reference	SWM/2019/0353/
Direct Line	0370 779 7497	Your reference	APP/19/00427
Date	18 November 2021	Email	SWM.consultee@hants.gov.uk

Dear Sir/Madam,

50 new dwellings together with access, landscaping and open space. at Land at Lower Road, Havant(Application No. APP/19/00427

Hampshire County Council as Lead Local Flood Authority has provided comments in relation to the above application in our role as statutory consultee on surface water drainage for major developments.

In order to assist applicants in providing the correct information to their Local Planning Authority for planning permission, Hampshire County Council has set out the information it requires to provide a substantive response at <https://www.hants.gov.uk/landplanningandenvironment/environment/flooding/planning>

The County Council has reviewed the following documents relating to the above application:

- Surface Water Management and Treatment ref: KTG/21:0355/5992 dated 2nd August 2021
- Up-Flo Filter Operation and Maintenance Manual
- Up-Flo Filter Sizing Calculator dated 19/12/2019
- SuDS Management & Maintenance Plan rev B
- Engineering Layout 1 of 5 ref: 5992:01 L
- Engineering Layout 2 of 5 ref: 5992:02 L
- Engineering Layout 3 of 5 ref: 5992:03 L
- Engineering Layout 4 of 5 ref: 5992:04 L
- Engineering Layout 5 of 5 ref: 5992:05 L
- Sections through Attenuation Basin, Reed Bed and Wet Pond ref: 5992:11 C
- Section through Soakaway Chamber ref: 5992:22 C

*Director of Economy, Transport and Environment
Stuart Jarvis BSc DipTP FCIHT MRTPI*

- Section through penstock and flow control chambers ref: 5992:23 B
- Email from MJA consulting confirming status of drainage strategy.

The above information has been provided to take into account comments raised previously. Based on this we would have no objection to the discharge of condition 6.

Condition 7 relates to the scheme of water quality monitoring which is outside of our remit and we would defer to the Environment Agency on this point. Therefore we have no comments in relation to this condition.

As a statutory consultee, the County Council has a duty to respond to consultations within **21 days**. The 21 day period will not begin until we have received sufficient information to enable us to provide a meaningful response.

Please ensure all data is sent to us via the relevant Local Planning Authority.

This response has been provided using the best knowledge and information submitted by the applicant as part of the planning application at the time of responding and is reliant on the accuracy of that information.

Yours faithfully,



Flood and Water Management Team
Economy, Transport & Environment Department,
Hampshire County Council, 1st Floor, Ell Court West,
The Castle, Winchester, Hampshire SO23 8UD
Web:

<https://www.hants.gov.uk/landplanningandenvironment/environment/flooding>

General guidance for the application

It is important to ensure that the long-term maintenance and responsibility for Sustainable Drainage Systems is agreed between the Local Planning Authority and the applicant before planning permission is granted. This should involve discussions with those adopting and/or maintaining the proposed systems, which could include the Highway Authority, Planning Authority, Parish Councils, Water Companies and private management companies.

For SuDS systems to be adopted by Hampshire Highways it is recommended that you visit the website at:

<https://www.hants.gov.uk/transport/developers/constructionstandards> for guidance on which drainage features would be suitable for adoption.

Where the proposals are connecting to an existing drainage system it is likely that the authorities responsible for maintaining those systems will have their own design requirements. These requirements will need to be reviewed and agreed as part of any surface water drainage scheme.

Works in relation to ordinary watercourses

*PLEASE NOTE: If the proposals include works to an ordinary watercourse, under the Land Drainage Act 1991, as amended by the Flood and Water Management Act 2010, prior consent from the Lead Local Flood Authority is required. **This consent is required as a separate permission to planning.***

Information on ordinary watercourse consenting can be found at the following link

<https://www.hants.gov.uk/landplanningandenvironment/environment/flooding/c/hangewatercourse>

It is strongly recommended that this information is reviewed before Land Drainage consent application is made.

*For guidance on providing the correct information, we recommend you use our **Ordinary Watercourse Consents Pre-application service** and help avoid delays occurring at the formal application stage. A Pre-application service for Ordinary Watercourse Consents is available, allowing consents to go through in a smoother, often more timely manner. For full information please visit:*

<https://www.hants.gov.uk/landplanningandenvironment/environment/flooding/c/hangewatercourse>