

Consultee Comments for Planning Application APP/20/01025

Application Summary

Application Number: APP/20/01025

Address: 62 Havant Road, Emsworth, PO10 7JG

Proposal: Erection of 1No. 3 bed detached dwelling with access from Beach Road.(15.04.21).

Request to discharge conditions 4 & 7(14.01.22).

Case Officer: Lesley Wells

Consultee Details

Name: Mrs Sally Nixon Building Control Team

Address: Public Service Plaza, Civic Centre Road, Havant PO9 2AX

Email: bct@havant.gov.uk

On Behalf Of: Building Control

Comments

The Foul and Surface water drainage are being taking into a combined system due to lack of space within the site

This is acceptable under the Building Regulations