



Result Overview, Inner Courtyard, 0M			
General		Average indirect fraction	
Calculation algorithm used		0.01 m	
Height of evaluation surface		0.80	
Maintenance factor			
Total luminous flux		7630 lm	
Total power		138.2 W	
Total power per area (23040.00 m²)		0.01 W/m²	
Illuminance			
Average illuminance	E _m	3.9 lx	
Minimum illuminance	E _{min}	0 lx	
Maximum illuminance	E _{max}	30.1 lx	
Uniformity U ₀	E _{min} /E _m	1:262 (0)	
Diversity U _d	E _{min} /E _{max}	1:2000 (0)	
Type No./Make			
THORN			
1	2 x	Order No. : 96632758 (STD - standard)	
		Luminaire name : PIAZZA II LED 1690-830 HF P ANT	
		Equipment : 1 x TL_PIA2-830 15C1W 15.1 W / 1815 lm	
Dextra Group PLC			
4	10 x	Order No. : !OPUWP L15 AS	
		Luminaire name : OPUS WALLPACK	
		Equipment : 1 x Dextra 10.8 W / 400 lm	
		Emergency : 647 lm (161.8 %)	

Result Overview, Walkway, 0M		
General		Average indirect fraction
Calculation algorithm used		0.01 m
Height of evaluation surface		0.80
Maintenance factor		
Total luminous flux		7630 lm
Total power		138.2 W
Total power per area (23040.00 m²)		0.01 W/m²
Illuminance		
Average illuminance	E _m	10.6 lx
Minimum illuminance	E _{min}	0 lx
Maximum illuminance	E _{max}	31.3 lx
Uniformity U ₀	E _{min} /E _m	1:230 (0)
Diversity U _d	E _{min} /E _{max}	1:679 (0)
Type No.Make		
THORN		
Order No.	: 96632758 (STD - standard)	
Luminaire name	: PIAZZA II LED 1690-830 HF P ANT	
Equipment	: 1 x TL_PIA2-830 15C1W 15.1 W / 1815 lm	
Dextra Group PLC		
Order No.	: !OPUWP L15 AS	
Luminaire name	: OPUS WALLPACK	
Equipment	: 1 x Dextra 10.8 W / 400 lm	
Emergency	: 647 lm (161.8 %)	

Notes		
Rev:	Date:	Description:
Drawn by: RF	Drawing Ref: 240101 0M.Exterior	
Date: 06.03.24	Drawing: Isoline Results, Plane set at 0M	
LIGHT TECH Ltd. Unit 11 Northam Business Centre Princes Street Southampton SO14 5RP Tel: 023 8033 4058 Fax: 023 8033 1984 email: rob@lighttech.co.uk		Project Ref: JNP Developments 11-15 South Street, Havant, PO9 1BU
		Scale:
© This drawing is not to be reproduced in whole or in part without written consent.		
light tech INDEPENDENT LIGHTING DESIGN		