

Mark Phelps
PDP Architecture llp
2 Beechworth Road
Havant
PO9 1AX

For: Ms Daughtrey
Nightingale Apartments Ltd

TOWN AND COUNTRY PLANNING ACT 1990 (AS AMENDED)
TOWN AND COUNTRY PLANNING (GENERAL PERMITTED DEVELOPMENT) (ENGLAND)
ORDER 2015

Prior Approval is Required and Hereby Given

Application Number: APP/24/00652

Site Address: Littlefold Family Resource Centre, Linnet Close, Waterlooville, PO8 9UY

Proposal: Prior Approval for development consisting of a change of use of a building and any land within its curtilage from Class E (commercial, business and service) (Class C3 dwellinghouses).

I refer to your notification on 21 August 2024 with regard to the above proposal and write to advise you that:

PRIOR APPROVAL IS REQUIRED AND HEREBY GIVEN

You are advised that under the provisions of Part 3, Class MA of the Town and Country Planning (General Permitted Development) Order 2015 (as amended), development is permitted subject to the following conditions:

(a) Development under Class MA must be completed within a period of 3 years starting with the prior approval date; and

(b) A building which has changed use under Class MA is to be used as a dwellinghouse within the meaning of Class C3 of the Schedule of the Use Classes Order and for no other purpose, except to the extent that the other purpose is ancillary to the primary use as such a dwellinghouse;

and is subject to compliance with:

- (i) The plans and other documents submitted with regard to your application; and
- (ii) The following conditions:

1 GENERAL

The development must be completed within a period of three years starting with the prior approval date.

Reason: To comply with the conditions contained within The Town and Country Planning (General Permitted Development) (England) Order 2015 Part 3 MA.2.

- 2 The building hereby permitted shall only be used as dwellinghouses by virtue of Class MA of the General Permitted Development Order 2015 (as amended) and shall remain in use as dwellinghouses within the meaning of Class C3 of Schedule 1 to the Use Classes Order and for no other purpose, except to the extent that the other purpose is ancillary to the use as a dwellinghouse.

Reason: To ensure that the building remains as dwellinghouses within the meaning of Class C3 of Schedule 1 to the Use Classes Order in accordance with Class MA of the General Permitted Development Order 2015 (as amended) and the National Planning Policy Framework.

- 3 The development hereby permitted shall be carried out in accordance with the following approved plans:

Plans

Proposed Site & Location Plan - Drawing No. 18177-PD011 Rev C
Proposed Plans & Elevations - Drawing No. 18177-PD012 Rev C
Site Plan - Drawing No. 28179-SK110 Rev A

Documents

Flood Risk Assessment by Kingfisher Property Group Ltd dated June 2024
Contamination Investigation Report by 40 Soils dated August 2024
Preliminary Investigation Report by 40 Soils Ltd dated July 2024
Nutrient Budget Calculator
European Site Avoidance & Mitigation Checklist
Occupancy Calculator
Noise Assessment Report by Auricl Acoustic Consulting dated 2 July 2024
Transport Statement by Nightingale Apartments Ltd dated July 2024
Email dated 15/1/25 confirming building vacated on 29 April 2024

Reason: To ensure provision of a satisfactory development.

- 4 The external materials used shall be as indicated on the submitted forms and hereby approved plans, or shall match, in type, colour and texture, those of the existing building so far as practicable.

Reason: In the interests of the amenities of the area and having due regard to policy CS16 of the Havant Borough Local Plan (Core Strategy) 2011 and the National Planning Policy Framework.

- 5 No floodlighting, street lighting or other form of external lighting scheme, including at or on dwelling units, shall be installed unless it has been approved by the Local Planning Authority. Such details shall include, Location, height, type and direction of light sources and intensity of illumination. Any lighting scheme agreed in writing by the Local Planning Authority shall not thereafter be altered without prior consent other

than for routine maintenance, which does not change its details.

Reason: To protect the occupants outside of and within the development from light disturbance / nuisance having due regard to Policies CS16 and DM10 of the Havant Borough Local Plan (Core Strategy) 2011 and the National Planning Policy Framework.

- 6 The car parking, servicing and other vehicular access arrangements shown on the approved plans to serve the development hereby permitted shall be made fully available for use prior to the development being first brought into use and shall be retained thereafter for their intended purpose.

Reason: In the interests of highway safety and having due regard to policy DM13 of the Havant Borough Local Plan (Core Strategy) 2011 and the National Planning Policy Framework.

7 **PRECOMMENCEMENT**

Prior to the commencement of development a Construction Management Plan shall be submitted and approved in writing by the Local Planning Authority. The plan should include, but not be limited to:

- a. Procedures for maintaining good public relations including complaint management, public consultation and liaison and site management contact details
- b. All works and ancillary operations which are audible at the site boundary, or at such other place as may be agreed with the Local Planning Authority, shall be carried out only between the following hours: 08:00 Hours and 18:00 Hours on Mondays to Fridays and 08:00 and 13:00 Hours on Saturdays and at no time on Sundays and Bank Holidays.
- c. Deliveries to and removal of materials, plant, equipment, machinery and waste from the site must only take place within the permitted hours detailed above.
- d. Mitigation measures as defined in BS 5528: Parts 1 and Part 2, 2009 and A1:2014 - Noise and Vibration Control on Construction and Open Sites shall be used to minimise noise disturbance from clearance and construction works.
- e. Procedures for emergency deviation of the agreed working hours
- f. Measures for controlling the use of site lighting during all phases, whether required for safe working or for security purposes, to ensure no impact on any nearby residential receptors;
- g. Control measures for dust and other air-borne pollutants. It should advise as to what measures are to be put in place for the control of any dust that might emanate from the development site. The methods of dust control should be in accordance with the guidance as laid out in the BRE Report 456 - Control of Dust from Construction and Demolition activities, and also the IAQM Guidance on the assessment of dust from demolition and construction 2014.
- h. No bonfires to take place on the site at any time;
- i. A scheme for recycling/disposing of waste resulting from demolition, clearance and construction works is to be implemented.

The approved plan shall be in operation throughout the development.

Reason: In the interests of amenity having due regard to Policies DM10 and CS16 of the Havant Borough Local Plan (Core Strategy) 2011 and the National Planning Policy Framework.

8 **PRIOR TO OCCUPATION**

Reasonable vigilance for the presence of contamination and soil hazards shall be maintained during all groundwork, service installation, and any work involving access to wall cavities or voids/soils below ground floor level. In the event that any suspected contamination (stained soils or fuel/solvent odour); works in affected areas of the site shall cease until the Local Planning Authority has been notified of the discovery and a scheme to deal with the risks associated with the suspected contamination has been submitted to- and approved in writing by- the Local Planning Authority.

The scheme may take a proportionate approach to the degree of formality adopted and may comprise separate results / reports / statements as appropriate, but unless specifically excluded by agreement shall include;

- 1) Investigation in the vicinity of the suspect material, sufficient to characterise it's nature, likely extent & mobility,
- 2) An appropriate assessment of the risks to all receptors that may be affected, based upon 1), and;
- 3) Where potentially unacceptable risks are identified by 2), a Remediation / Risk Management Strategy that includes appropriately considered remedial objectives and clearly defined proposals for achieving these, having due regard to sustainability

All investigation, assessments & other actions required by 1)-3) above (and B, below) shall be undertaken & recorded by competent persons, and the findings presented in a written format. The scheme shall be implemented as approved.

Prior to the occupation of any relevant part of the permitted development, EITHER of the following shall be submitted to the Local Planning Authority;

- A) A written statement confirming that no suspected contamination was identified during development, OR;
- B) Documentation in accordance with 1) & 2) above; together with a Verification Report (where appropriate) which demonstrates that the agreed remediation objectives (3)) have been met.

Reason: Site investigation has not ruled out the possibility of discrete deposits of fuel contamination associated with the building's former heating systems. Such a deposit could pose a risk to future occupiers of ground-floor units, &/or to the local water environment. This is in line with DM10 of the Havant Borough Local Plan (Core Strategy) 2011, DM17 of the Havant Borough Local Plan (Allocations) [2014], and paragraphs 196 & 197 of the National Planning Policy Framework 2024

9

The development hereby permitted shall not be occupied until:

- (a) A water efficiency calculation in accordance with the Government's National Calculation Methodology for assessing water efficiency in new dwellings has been undertaken which demonstrates that no more than 110 litres of water per person per day shall be consumed within the development, and this calculation has been submitted to, and approved in writing by, the Local Planning Authority; and
- (b) All measures necessary to meet the approved water efficiency calculation have been installed.

Reason: There is existing evidence of high levels of nitrogen and phosphorus in the water environment with evidence of eutrophication at some European designated

nature conservation sites in the Solent catchment. The PUSH Integrated Water Management Strategy has identified that there is uncertainty as to whether new housing development can be accommodated without having a detrimental impact on the designated sites within the Solent. Further detail regarding this can be found in the appropriate assessment that was carried out regarding this planning application.

In compliance with Regulation 63 of the Conservation of Habitats and Species Regulations 2017, the local planning authority has a duty to ensure that sufficient mitigation is provided against any impacts which might arise upon the designated sites. In coming to this decision, the Council has also had regard to Policy CS11 of the Havant Borough Local Plan (Core Strategy) 2011.

10 POST OCCUPANCY

At all times following occupation of the development hereby approved, all measures for water usage within the submitted nutrient budget shall be maintained in the development in perpetuity.

Reason: There is existing evidence of high levels of nitrogen and phosphorus in the water environment with evidence of eutrophication at some European designated nature conservation sites in the Solent catchment. The PUSH Integrated Water Management Strategy has identified that there is uncertainty as to whether new housing development can be accommodated without having a detrimental impact on the designated sites within the Solent. Further detail regarding this can be found in the appropriate assessment that was carried out regarding this planning application. In compliance with Regulation 63 of the Conservation of Habitats and Species Regulations 2017, the local planning authority has a duty to ensure that sufficient mitigation is provided against any impacts which might arise upon the designated sites. In coming to this decision, the Council has also had regard to Policy CS11 of the Havant Borough Local Plan (Core Strategy) 2011.

Other Important Information:

- (1) This notice only relates to the decision of Havant Borough Council as Local Planning Authority under the Town and Country Planning Acts. It does not relate to any other application that may be required under the Building Regulations or under any other Act, Regulation, Byelaw or Order where the Council's approval may be needed. For further guidance as to the need for consent under the Building Regulations please phone 023 9244 6571.
- (2) Your attention is drawn to the attached information regarding firstly your right to appeal to the Planning Inspectorate, if you are aggrieved by the Council's decision, and secondly the rights of an owner to, in certain circumstances serve a purchase notice on the Council. See www.planningportal.gov.uk/pes.
- (3) Any failure to adhere to the details of the approved plans, and other documents or to comply with any conditions listed above may lead to enforcement action being taken by the Council. If you wish to depart from the approved details or conditions in any way you should contact the Planning and Development service at the Plaza or by telephoning 023 9244 6015.
- (4) In accordance with paragraphs 38-50 of the NPPF Havant Borough Council (HBC) takes a positive and proactive approach and works with applicants/agents on

development proposals in a manner focused on solutions by:

- Offering a pre-application advice service, and
- Updating you of any issues that may arise in the processing of your application and where possible suggesting solutions, and,

In this instance: You were updated about issues after the initial site visit.

Alex Robinson

Alex Robinson
Executive Head of Place

17 January 2025

TOWN AND COUNTRY PLANNING ACT 1990

NOTIFICATION TO BE SENT TO AN APPLICANT WHEN A LOCAL PLANNING AUTHORITY REFUSE PLANNING PERMISSION OR GRANT IT SUBJECT TO CONDITIONS

- These notes are for information only and do not purport to set out the law on the subject.
- Only the applicant possesses the right of appeal.

Appeals to the Secretary of State

- If you are aggrieved by the decision of your local planning authority to refuse permission for the proposed development or to grant it subject to conditions, then you can appeal to the Secretary of State under section 78 of the Town and Country Planning Act 1990.
- If this is a decision on a planning application relating to the same or substantially the same land and development as is already the subject of an enforcement notice and you want to appeal against your local planning authority's decision on your application, then you must do so within 28 days of the date of this notice.
- If an enforcement notice is served relating to the same or substantially the same land and development as in your application and if you want to appeal against your local planning authority's decision on your application, then you must do so within 28 days of the date of service of the enforcement notice, or within 6 months [12 weeks in the case of a householder appeal] of the date of this notice, whichever period expires earlier.
- If this is a decision to refuse planning permission for a householder application and you want to appeal against your local planning authority's decision then you must do so within 12 weeks of the date of this notice.
- If this is a decision to refuse planning permission for a minor commercial application and you want to appeal against your local planning authority's decision then you must do so within 12 weeks of the date of this notice.
- If this is a decision to refuse express consent for the display of an advertisement and you want to appeal against your local planning authority's decision then you must do so within 8 weeks of the date of receipt of this notice.
- If this is a decision to refuse consent to work on a tree which is subject to a Tree Preservation Order and you want to appeal against your local planning authority's decision then you must do so within 28 days of the date of this notice.
- If this is a decision to refuse any other type of application and you want to appeal against your local planning authority's decision then you must do so within 6 months of the date of this notice.
- **Appeals can be made online at:** <https://www.gov.uk/appeal-householder-planning-decision> for householder applications; <https://www.gov.uk/appeal-planning-decision> for full applications; <https://www.gov.uk/planning-inspectorate> for anything else.
- The Secretary of State can allow a longer period for giving notice of an appeal but will not normally be prepared to use this power unless there are special circumstances which excuse the delay in giving notice of appeal.
- The Secretary of State need not consider an appeal if it seems to the Secretary of State that the local planning authority could not have granted planning permission for the proposed development or could not have granted it without the conditions they imposed, having regard to the statutory requirements, to the provisions of any development order and to any directions given under a development order.

If you intend to submit an appeal that you would like examined by inquiry, then you must notify the Local Planning Authority and Planning Inspectorate (inquiryappeals@planninginspectorate.gov.uk) at least 10 days before submitting the appeal. [Further details are on GOV.UK.](#)

Our Ref: APP/24/00652

IMPORTANT NOTICE FOR APPLICANTS WITH REGARD TO BUILDING REGULATIONS

This notice only relates to the decision of Havant Borough Council under the Town and Country Planning Acts. It does not relate to any other application that may be required any other Act, Regulation, Byelaw or Order where the Council's approval may be needed.

For further guidance as the need for consent under the Building Regulations, please telephone Havant Borough Council's Building Control team on:

023 9244 6571

Southern Gas advisory note

In June 2021 SGN issued a comprehensive advisory note

There are a number of risks created by built over gas mains and services; these are:

- Pipework loading - pipes are at risk from loads applied by the new structure and are more susceptible to interference damage.
- Gas entry into buildings - pipework proximity increases risk of gas entry in buildings. Leaks arising from previous external pipework able to track directly into main building from unsealed entry.
- Occupier safety - lack or no fire resistance of pipework, fittings, or meter installation. Means of escape could be impeded by an enclosed meter.

Please note therefore, if you plan to dig, or carry out building work to a property, site, or public highway within our gas network, you must:

1. Check your proposals against the information held at <https://www.linerearchbeforeudig.co.uk/> to assess any risk associated with your development and
2. Contact our Plant Protection team to let them know. Plant location enquiries must be made via email, but you can phone us with general plant protection queries. See our contact details below:

Phone: 0800 912 1722 / Email: plantlocation@sgn.co.uk

In the event of an overbuild on our gas network, the pipework must be altered, you may be temporarily disconnected, and your insurance may be invalidated.

Further information on safe digging practices can be found here:

- Our free Damage Prevention e-Learning only takes 10-15 minutes to complete and highlights the importance of working safely near gas pipelines, giving clear guidance on what to do and who to contact before starting any work
<https://www.sgn.co.uk/damage-prevention>
- Further information can also be found here
<https://www.sgn.co.uk/help-and-advice/digging-safely>

SGN personnel will contact you accordingly.