

Havant Borough Council
Civic Offices
Civic Centre Road
Havant
PO9 2AX

Hampshire 2050
The Castle
Winchester, Hampshire SO23 8UD

Telephone: 0300 555 1375
Fax: 01962 847055

www.hants.gov.uk

Enquiries To Ray Alborough

Direct Line

Date 4 March 2024

My reference

Your
reference

Email

APP/24/00130

havantdc@hants.gov.uk

Dear Josephine,

2 Towers Garden, Havant, PO9 1RZ

Installation of a hard stand/drive on part of the front garden to support the charging of electric vehicles.

I refer to your consultation in respect of the above.

This site already has a dropped kerb vehicular access. The mock up of the drive indicates a block paved surface material, subject to the detailed levels ensuring the drive area does not drain onto the highway I can confirm the Highway Authority have no objection subject to the following condition :-

During the construction period and prior to the first use of the drive the means of drainage shall ensure no surface water spills out onto the adjacent highway.

If you think it is appropriate a detailed level plan could be sought and/or the scheme could show interception drainage.

Yours sincerely,

Ray. Alborough