

Consultee Comments for Planning Application APP/24/00237

Application Summary

Application Number: APP/24/00237

Address: Land at Hermitage Park, Harts Farm Way, Havant

Proposal: Proposed Gas fuelled Capacity Mechanism embedded generation plant to support the National Grid. A resubmission of previously approved applications (APP/21/00809) in order to secure changes to the site layout and technology following transfer of ownership of the site.

Case Officer: Joseph Toole

Consultee Details

Name: Consultee HBC Drainage Civil Engineering Team Leader

Address: Public Service Plaza, Civic Centre Road, Havant PO9 2AX

Email: Not Available

On Behalf Of: Engineering/Drainage

Comments

No land drainage observations. However Flood Risk Assessment para 3.7.1 is incorrect in that the nearest main river is immediately adjacent to the north-west boundary of the site (picked up in 3.7.3 as a 'minor feature') and as such the applicant will require consent from the EA for works within the offset of the river.