



Department of Planning and Development
Havant Borough Council
Public Service Plaza
Civic Centre Road
Havant
Hampshire
PO9 2AX

Your ref
APP/22/00472

Our ref
DSA000012951

Date
01/07/2022

Contact
Tel 0330 303 0119

Dear Sir/Madam,

Proposal: Construction of front porch and loft conversion with front and rear dormer.

Site: APP/22/00472: - 90 Haslar Crescent, Waterlooville, PO7 6DH.

Thank you for your letter dated 13/06/2022.

The attached plan shows that the existing building lies over an existing public foul sewer. If the works to be carried out will alter the existing foundation line or depth or the structural load applied on the sewer it will be necessary for the applicant to contact Southern Water.

It is possible that a sewer now deemed to be public could be crossing the development site. Therefore, should any sewer be found during construction works, an investigation of the sewer will be required to ascertain its ownership before any further works commence on site.

For further advice, please contact Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX (Tel: 0330 303 0119).

Website: southernwater.co.uk or by email at: SouthernWaterPlanning@southernwater.co.uk

Yours faithfully,

Future Growth Planning Team
Business Channels

southernwater.co.uk/developing-building/planning-your-development

