

RE: Planning Application APP/21/00989 Cabbagefield Row, opposite 123-133,
Swanmore Road, Havant

FWM Statutory SWM Consultee mailbox

Thank you for consulting us on the amended details for this application. Having reviewed these, we have the following comments:

There appears to be a discrepancy between the drainage layout and the calculations for SWMH14 regarding the discharge rate allowed by the northern catchment Hydro-Brake. Also the calculations show that surface water floods at this manhole for all storm events, this would only be acceptable during the 1 in 100 year event. This may be resolvable by increasing the attenuation storage volume upstream.

If these details can be resolved we can remove our objection.

Regards

Tom Callaway