

HAVANT BOROUGH COUNCIL

Town & Country Planning Act 1990

Consultation on Planning Application

MEMORANDUM

From: Environmental Health **To:** Development Control

Our Ref: CONS/22/01383 **Your Ref:** APP/21/01188

EH Case Officer Extn: 44 6666 **Date:** 30 June 2022

DC Case Officer: Mr J. Toole

DC Case Officer Extn: 802

Application Number: APP/21/01188

Site Address: 1 Park Way, Havant, PO9 1HH

Proposed Development: **Site Address:** 1 Park Way, Havant, PO9 1HH

Proposed Development: Proposed extraction equipment to rear of unit, shopfront alterations, and variation of Condition 1 of Planning Permission 06/59412/008 to allow premises to open to the public from 11:00 to 23:00 each day of the week.(22.02.22).Request to discharge condition 3 (22.04.22).

Observations / Comments:

I have read the acoustic report submitted for the purpose of discharging Condition 3 of the decision notice dated 22 February 2022. A Plant noise assessment dated March 2022, was carried out by Hepworth Acoustics Ltd, and includes the extract & inlet fan systems, and condenser units.

It is advised in the assessment, that no additional mitigation measures, other than the proposed fan attenuators, will be required, to ensure that the stipulations within Condition 3 can be met.

As such, this office is of the opinion that condition 3 can be discharged.

However it will remain up to the applicant to ensure, that the proposed fan attenuators are installed as advised.

Mr. Mark Moss

Regulatory Officer, Environmental Health