

Dear David

I have reviewed the information provided however there is still an outstanding query in relation to the flooding anticipated at the 1:100 + climate change storm. This flooding should be identified on either the drainage plan or exceedance flow routing plan and evidence provided to demonstrate how it can be effectively managed on site. This issue was highlighted in our response of 19th May 22.

Regards

Sarah

Sarah Reghif
Flood and Water Management
0370 779 7497
SWM.consultee@hants.gov.uk

Economy Transport and Environment
EII Court West
The Castle
Winchester
Hampshire
SO23 8UD

Hampshire Services offers a range of professional consultancy services to partner organisations.
www.hants.gov.uk/sharedexpertise

Copyright Hampshire County Council 2004 Disclaimer Privacy Statement