



Department of Planning and Development
Havant Borough Council
Public Service Plaza
Civic Centre Road
Havant
Hampshire
PO9 2AX

Your ref
APP/22/00209

Our ref
DSA000010566

Date
25/04/2022

Contact
Tel 0330 303 0119

Dear Sir/Madam,

Proposal: Double garage and garden building.

Site: APP/22/00209: - 161A West Lane, Hayling Island, PO11 0JW.

Thank you for your letter dated 06/04/2022.

There are no public foul and surface water sewers in the area to serve this development. The applicant is advised to examine alternative means of foul and surface water disposal.

The Environment Agency should be consulted directly regarding the use of a private wastewater treatment works or septic tank drainage which disposes of effluent to sub-soil irrigation. The owner of the premises will need to empty and maintain the works or septic tank to ensure its long term effectiveness.

It is possible that a sewer now deemed to be public could be crossing the development site. Therefore, should any sewer be found during construction works, an investigation of the sewer will be required to ascertain its ownership before any further works commence on site.

For further advice, please contact Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX (Tel: 0330 303 0119).

Website: southernwater.co.uk or by email at: SouthernWaterPlanning@southernwater.co.uk

Yours faithfully,

Future Growth Planning Team
Business Channels

southernwater.co.uk/developing-building/planning-your-development

SOUTHERN WATER



The positions of pipes shown on this plan are believed to be correct, but Southern Water Services Ltd accept no responsibility in the event of inaccuracy. The actual positions should be determined on site.

Based upon Ordnance Survey Digital Data with the permission of the controller of H.M.S.O. Crown Copyright Reserved Licence No. WU 298530

O.S. REF: SU7100NW

Scale: 1:1250

Screen Print

WARNING: BAC pipes are constructed of Bonded Asbestos Cement

WARNING: Unknown (UNK) materials may include Bonded Asbestos Cement



Printed By: rudraps

Date: 21-4-2022

Southern Water MapGuide Browser

Requested By:

