

Hampshire County Council

Proposed Connection Schedule

07 February 2022

South Downs College (Car Park 6) - Proposed Lighting - Equipment Schedule - R1

Proposed Unit No.	Easting Coordinates	Northing Coordinates	Service Connection Type	Location	Unit Description	Isolator Type	Termination Type
P1	468944.84	107284.72	Private supply TBC by others	As Per MMA17011 Layout Drawing	Proposed 6m standard steel column with post top mounted DW Windsor Kirium Pro1 C2 6.34klm NW LED.	Standard Double Pole Isolator	TBC by others
P2	468970.07	107280.14	Private supply TBC by others	As Per MMA17011 Layout Drawing	Proposed 6m standard steel column with post top mounted DW Windsor Kirium Pro1 C2 6.34klm NW LED.	Standard Double Pole Isolator	TBC by others
P3	468996.1	107275.8	Private supply TBC by others	As Per MMA17011 Layout Drawing	Proposed 6m standard steel column with post top mounted DW Windsor Kirium Pro1 C2 6.34klm NW LED.	Standard Double Pole Isolator	TBC by others
P4	468947.27	107311.18	Private supply TBC by others	As Per MMA17011 Layout Drawing	Proposed 6m standard steel column with post top mounted DW Windsor Kirium Pro1 C2 6.34klm NW LED.	Standard Double Pole Isolator	TBC by others
P5	468976.76	107307.1	Private supply TBC by others	As Per MMA17011 Layout Drawing	Proposed 6m standard steel column with post top mounted DW Windsor Kirium Pro1 C2 6.34klm NW LED.	Standard Double Pole Isolator	TBC by others
P6	469003.63	107302.54	Private supply TBC by others	As Per MMA17011 Layout Drawing	Proposed 6m standard steel column with post top mounted DW Windsor Kirium Pro1 C2 6.34klm NW LED.	Standard Double Pole Isolator	TBC by others

NOTE: NUMBERS SHOWN ON THE SCHEDULE AND DESIGN DRAWING ARE FOR IDENTIFICATION PURPOSES ONLY - ACTUAL COLUMN NUMBERS TO BE SPECIFIED BY LOCAL AUTHORITY LIGHTING DEPARTMENT OR OVERSEEING ORGANISATION.