

Thank you Selina

The response has addressed our concerns and we wish to withdraw our objection provided the following condition is attached,

The rating level of the noise emitted from the plant (as detailed in noise report KD1001227NR 17/02/2022) shall not exceed the existing background sound level determined to be 39 LA90,(15 min) Monday to Sunday. The noise levels shall be determined at noise sensitive receptors NSR1, 2 and 4 as identified in the noise report. The rating level of the noise emitted from the plant shall not exceed 40 dBA Monday to Sunday at NSR3 as identified in the noise report. The measurements and assessment shall be made according to BS 4142:2014+A1:2019.

Note: this condition does not apply to the noise emitted from the emergency generators.

Regards

Helen Le-Vallee

Environmental Health Officer

Direct Dial: 01730 234302