



Department of Planning and Development
Havant Borough Council
Public Service Plaza
Civic Centre Road
Havant
Hampshire
PO9 2AX

Your ref
APP/22/00183

Our ref
DSA000010558

Date
12/04/2022

Contact
Tel 0330 303 0119

Dear Sir/Madam,

Proposal: Single storey rear extension. (Revised application).
Site: APP/22/00183: - 1 New Cut, Hayling Island, PO11 0NB.

Further to our previous correspondence dated 31/03/2022 regarding the above planning consultation and further information provided by the developer regarding position of sewers, it shows that the proposed extension is not within 3m easement zone.

The submitted site plan (drawing no.18071-432) shows that the existing building lies close to an existing public foul sewer. If the works to be carried out will alter the existing foundation line or depth or the structural load applied on the sewer it will be necessary for the applicant to contact Southern Water.

All other comments in our previous response dated 31/03/2022 remain unchanged and valid.

For further advice, please contact Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX (Tel: 0330 303 0119).

Website: southernwater.co.uk or by email at: SouthernWaterPlanning@southernwater.co.uk

Your faithfully,

Future Growth Planning Team
Business Channels

southernwater.co.uk/developing-building/planning-your-development