

Consultee Comments for Planning Application APP/20/00551

Application Summary

Application Number: APP/20/00551

Address: Land adjacent to 1 Westland Drive, Waterloooville, PO7 5UG

Proposal: Construction of 1No. detached 3 bedroom dwelling with associated parking and access, landscaping and refuse cycle store (Approved 13/07/2022). Request to Discharge Conditions 5, 7 and 12 (20/12/2022).

Case Officer: Lesley Wells

Consultee Details

Name: Mrs Sally Nixon Building Control Team

Address: Public Service Plaza, Civic Centre Road, Havant PO9 2AX

Email: Not Available

On Behalf Of: Building Control

Comments

These work will require Building Regulation consent

Previous comments still relevant :

Comment Date: Wed 22 Jul 2020

It should be ensured that the South elevation is at least 1m from the site boundary. If closer than 1m the unprotected area of the wall formed by windows and doors in more than permitted.