

Consultee Comments for Planning Application APP/20/00658

Application Summary

Application Number: APP/20/00658

Address: Proposed Development site (former Electricity Board site), Bartons Road, Havant

Proposal: Proposed development of 175 apartments together with associated access, parking and landscaping.

Case Officer: David Eaves

Consultee Details

Name: Mrs Sally Nixon Building Control Team

Address: Public Service Plaza, Civic Centre Road, Havant PO9 2AX

Email: bct@havant.gov.uk

On Behalf Of: Building Control

Comments

Building Regulation consent required

Householders should not have to carry containers more than 30m (excluding vertical distance) to waste collection point. Carrying containers through a builder is not allowed unless garage or some form of covered way AD H Section 6 para 1.8 & 1.9. Unable to scale plan to assess compliance