

A consultee has commented on a Planning Application. A summary of the comments is provided below.

Comments were submitted at 9:33 AM on 11 May 2022 from Mrs Sally Nixon Building Control Team (bct@havant.gov.uk) on behalf of Building Control.

Application Summary

Reference: APP/20/01025

Address: 62 Havant Road, Emsworth, PO10 7JG

Proposal: Erection of 1No. 3 bed detached dwelling with access from Beach Road.(15.04.21). Request to discharge conditions 4 & 7(14.01.22).

Case Officer: Lesley Wells

[Click for further information](#)

Comments Details

Comments: The Foul and Surface water drainage are being taking into a combined system due to lack of space within the site

This is acceptable under the Building Regulations