

H2OK Systems Limited		Page 1
Nanjerrick Court Allet, Truro TR4 9DJ		
Date 19/06/2018 14:09 File Trench 4.srcx	Designed by HShort Checked by	

Micro Drainage Source Control 2017.1.2

Summary of Results for 100 year Return Period (+40%)

Half Drain Time : 2 minutes.

Storm Event	Max Level (m)	Max Depth (m)	Max Infiltration (l/s)	Max Control (l/s)	Max Overflow (l/s)	Max Σ Outflow (l/s)	Max Volume (m³)	Status
15 min Summer	2.543	0.343	0.0	47.3	0.0	47.3	4.4	0 K
30 min Summer	2.545	0.345	0.0	48.4	0.0	48.4	4.5	0 K
60 min Summer	2.530	0.330	0.0	40.8	0.0	40.8	4.1	0 K
120 min Summer	2.514	0.314	0.0	31.4	0.0	31.5	3.7	0 K
180 min Summer	2.497	0.297	0.0	20.5	0.0	20.6	3.3	0 K
240 min Summer	2.441	0.241	0.0	18.2	0.0	18.3	2.2	0 K
360 min Summer	2.393	0.193	0.0	14.0	0.0	14.0	1.4	0 K
480 min Summer	2.363	0.163	0.0	11.6	0.0	11.6	1.0	0 K
600 min Summer	2.347	0.147	0.0	9.6	0.0	9.6	0.8	0 K
720 min Summer	2.332	0.132	0.0	8.6	0.0	8.6	0.7	0 K
960 min Summer	2.316	0.116	0.0	6.7	0.0	6.7	0.5	0 K
1440 min Summer	2.296	0.096	0.0	5.4	0.0	5.4	0.3	0 K
2160 min Summer	2.282	0.082	0.0	3.8	0.0	3.8	0.3	0 K
2880 min Summer	2.273	0.073	0.0	3.4	0.0	3.4	0.2	0 K
4320 min Summer	2.260	0.060	0.0	2.4	0.0	2.4	0.1	0 K
5760 min Summer	2.260	0.060	0.0	2.4	0.0	2.4	0.1	0 K
7200 min Summer	2.252	0.052	0.0	1.9	0.0	1.9	0.1	0 K
8640 min Summer	2.244	0.044	0.0	1.4	0.0	1.4	0.1	0 K
10080 min Summer	2.244	0.044	0.0	1.2	0.0	1.2	0.1	0 K
15 min Winter	2.554	0.354	0.0	52.0	0.0	52.1	4.7	0 K

Storm Event	Rain (mm/hr)	Flooded Volume (m³)	Discharge Volume (m³)	Overflow Volume (m³)	Time-Peak (mins)
15 min Summer	124.633	0.0	28.0	0.0	12
30 min Summer	83.789	0.0	37.7	0.0	20
60 min Summer	53.779	0.0	48.4	0.0	34
120 min Summer	33.337	0.0	60.0	0.0	64
180 min Summer	24.832	0.0	67.0	0.0	98
240 min Summer	20.006	0.0	72.0	0.0	128
360 min Summer	14.706	0.0	79.4	0.0	186
480 min Summer	11.818	0.0	85.1	0.0	244
600 min Summer	9.966	0.0	89.7	0.0	308
720 min Summer	8.665	0.0	93.6	0.0	368
960 min Summer	6.943	0.0	100.0	0.0	490
1440 min Summer	5.071	0.0	109.5	0.0	726
2160 min Summer	3.696	0.0	119.8	0.0	1088
2880 min Summer	2.949	0.0	127.4	0.0	1440
4320 min Summer	2.142	0.0	138.8	0.0	2196
5760 min Summer	1.705	0.0	147.3	0.0	3160
7200 min Summer	1.427	0.0	154.0	0.0	3824
8640 min Summer	1.235	0.0	159.6	0.0	4296
10080 min Summer	1.093	0.0	165.0	0.0	5104
15 min Winter	124.633	0.0	31.4	0.0	13

H2OK Systems Limited		Page 3																																				
Nanjerrick Court Allet, Truro TR4 9DJ																																						
Date 19/06/2018 14:09 File Trench 4.srcx	Designed by HShort Checked by																																					
Micro Drainage		Source Control 2017.1.2																																				
<u>Rainfall Details</u> <table> <tr> <td>Rainfall Model</td> <td>FSR</td> <td>Winter Storms</td> <td>Yes</td> </tr> <tr> <td>Return Period (years)</td> <td>100</td> <td>Cv (Summer)</td> <td>0.750</td> </tr> <tr> <td>Region</td> <td>England and Wales</td> <td>Cv (Winter)</td> <td>0.840</td> </tr> <tr> <td>M5-60 (mm)</td> <td>19.000</td> <td>Shortest Storm (mins)</td> <td>15</td> </tr> <tr> <td>Ratio R</td> <td>0.350</td> <td>Longest Storm (mins)</td> <td>10080</td> </tr> <tr> <td>Summer Storms</td> <td>Yes</td> <td>Climate Change %</td> <td>+40</td> </tr> </table> <u>Time Area Diagram</u> Total Area (ha) 0.120 <table> <thead> <tr> <th>Time (mins)</th> <th>Area</th> <th>Time (mins)</th> <th>Area</th> </tr> <tr> <th>From: To:</th> <th>(ha)</th> <th>From: To:</th> <th>(ha)</th> </tr> </thead> <tbody> <tr> <td>0 4</td> <td>0.060</td> <td>4 8</td> <td>0.060</td> </tr> </tbody> </table>			Rainfall Model	FSR	Winter Storms	Yes	Return Period (years)	100	Cv (Summer)	0.750	Region	England and Wales	Cv (Winter)	0.840	M5-60 (mm)	19.000	Shortest Storm (mins)	15	Ratio R	0.350	Longest Storm (mins)	10080	Summer Storms	Yes	Climate Change %	+40	Time (mins)	Area	Time (mins)	Area	From: To:	(ha)	From: To:	(ha)	0 4	0.060	4 8	0.060
Rainfall Model	FSR	Winter Storms	Yes																																			
Return Period (years)	100	Cv (Summer)	0.750																																			
Region	England and Wales	Cv (Winter)	0.840																																			
M5-60 (mm)	19.000	Shortest Storm (mins)	15																																			
Ratio R	0.350	Longest Storm (mins)	10080																																			
Summer Storms	Yes	Climate Change %	+40																																			
Time (mins)	Area	Time (mins)	Area																																			
From: To:	(ha)	From: To:	(ha)																																			
0 4	0.060	4 8	0.060																																			
©1982-2017 XP Solutions																																						

H2OK Systems Limited		Page 4																																				
Nanjerrick Court Allet, Truro TR4 9DJ																																						
Date 19/06/2018 14:09 File Trench 4.srcx	Designed by HShort Checked by																																					
Micro Drainage		Source Control 2017.1.2																																				
<u>Model Details</u> Storage is Online Cover Level (m) 3.000 <u>Infiltration Trench Structure</u> <table> <tr> <td>Infiltration Coefficient Base (m/hr)</td> <td>0.00100</td> <td>Trench Width (m)</td> <td>0.5</td> </tr> <tr> <td>Infiltration Coefficient Side (m/hr)</td> <td>0.00100</td> <td>Trench Length (m)</td> <td>294.0</td> </tr> <tr> <td>Safety Factor</td> <td>2.0</td> <td>Slope (1:X)</td> <td>500.0</td> </tr> <tr> <td>Porosity</td> <td>0.30</td> <td>Cap Volume Depth (m)</td> <td>0.000</td> </tr> <tr> <td>Invert Level (m)</td> <td>2.200</td> <td>Cap Infiltration Depth (m)</td> <td>0.000</td> </tr> </table> <u>Pipe Outflow Control</u> <table> <tr> <td>Diameter (m)</td> <td>0.300</td> <td>Entry Loss Coefficient</td> <td>0.500</td> </tr> <tr> <td>Slope (1:X)</td> <td>1000.0</td> <td>Coefficient of Contraction</td> <td>0.600</td> </tr> <tr> <td>Length (m)</td> <td>10.000</td> <td>Upstream Invert Level (m)</td> <td>2.200</td> </tr> <tr> <td>Roughness k (mm)</td> <td>0.600</td> <td></td> <td></td> </tr> </table> <u>Weir Overflow Control</u> Discharge Coef 0.544 Width (m) 10.000 Invert Level (m) 3.000			Infiltration Coefficient Base (m/hr)	0.00100	Trench Width (m)	0.5	Infiltration Coefficient Side (m/hr)	0.00100	Trench Length (m)	294.0	Safety Factor	2.0	Slope (1:X)	500.0	Porosity	0.30	Cap Volume Depth (m)	0.000	Invert Level (m)	2.200	Cap Infiltration Depth (m)	0.000	Diameter (m)	0.300	Entry Loss Coefficient	0.500	Slope (1:X)	1000.0	Coefficient of Contraction	0.600	Length (m)	10.000	Upstream Invert Level (m)	2.200	Roughness k (mm)	0.600		
Infiltration Coefficient Base (m/hr)	0.00100	Trench Width (m)	0.5																																			
Infiltration Coefficient Side (m/hr)	0.00100	Trench Length (m)	294.0																																			
Safety Factor	2.0	Slope (1:X)	500.0																																			
Porosity	0.30	Cap Volume Depth (m)	0.000																																			
Invert Level (m)	2.200	Cap Infiltration Depth (m)	0.000																																			
Diameter (m)	0.300	Entry Loss Coefficient	0.500																																			
Slope (1:X)	1000.0	Coefficient of Contraction	0.600																																			
Length (m)	10.000	Upstream Invert Level (m)	2.200																																			
Roughness k (mm)	0.600																																					
©1982-2017 XP Solutions																																						

H2OK Systems Limited		Page 5
Nanjerrick Court Allet, Truro TR4 9DJ		
Date 19/06/2018 14:09 File Trench 4.srcx	Designed by HShort Checked by	
Micro Drainage		Source Control 2017.1.2

Event: 15 min Winter

