

Havant Borough Council
Development Control
Civic Offices Civic Centre Road
Havant
Hampshire
PO9 2AX

Our ref: HA/2021/123555/01-L01
Your ref: APP/21/00913
Date: 27 September 2021

Dear Sir/Madam

VARIATION OF CONDITIONS 2 (APPROVED PLANS), 5 (LANDSCAPING), 9 (MATERIALS), 10 (HARDSURFACING) AND 15 (MEANS OF ENCLOSURE) OF PLANNING PERMISSION APP/20/01223 (DEMOLITION OF EXISTING DWELLING AND ERECTION OF REPLACEMENT DWELLING INCLUDING NEW SUMMER HOUSE AND GARAGE TOGETHER WITH NEW DRIVEWAY ACCESS WITH ASSOCIATED LANDSCAPING) - TO INCLUDE PROVISION OF FIRST FLOOR ACCOMMODATION OVER GARAGE AND REVISED SUMMERHOUSE AND TERRACE ARRANGEMENTS WITH NEW SEA WALL 48 SINAH LANE, HAYLING ISLAND, PO11 0HH

Thank you for consulting the Environment Agency on the above application.

We have reviewed the information as submitted and set out our position below.

Environment Agency Position

Our response to the original planning application dated 09 March 2021 remains unchanged after assessing the updates made in this planning application.

Advice to Applicant

Environmental Permit

The Environmental Permitting (England and Wales) Regulations 2016 require a permit or exemption to be obtained for any activities which will take place:

- on or within 8 metres of a main river (16 metres if tidal)
- on or within 8 metres of a flood defence structure or culverted main river (16 metres if tidal)
- on or within 16 metres of a sea defence

Environment Agency
Guildbourne House Chatsworth Road, Worthing, West Sussex, BN11 1LD.
Customer services line: 03708 506 506
www.gov.uk/environment-agency

Cont/d..

- involving quarrying or excavation within 16 metres of any main river, flood defence (including a remote defence) or culvert
- in a floodplain more than 8 metres from the river bank, culvert or flood defence structure (16 metres if it's a tidal main river) and you don't already have planning permission

For further guidance please visit <https://www.gov.uk/guidance/flood-risk-activities-environmental-permits> or contact our National Customer Contact Centre on 03708 506 506 (Monday to Friday, 8am to 6pm) or by emailing enquiries@environment-agency.gov.uk.

The applicant should not assume that a permit will automatically be forthcoming once planning permission has been granted, and we advise them to consult with us at the earliest opportunity.

Advice to LPA/Applicant **Flood resistance and resilience**

We strongly recommend the use of flood resistance and resilience measures. Physical barriers, raised electrical fittings and special construction materials are just some of the ways you can help reduce flood damage.

To find out which measures will be effective for this development, please contact your building control department. In the meantime, if you'd like to find out more about reducing flood damage, visit the Flood Risk and Coastal Change pages of the planning practice guidance. The following documents may also be useful:

Department for Communities and Local Government: Preparing for floods
<http://www.planningportal.gov.uk/uploads/odpm/4000000009282.pdf>

Department for Communities and Local Government: Improving the flood performance of new buildings: <https://www.gov.uk/government/publications/flood-resilient-construction-of-new-buildings>

Signing up for flood warnings

The applicant/occupants should phone Floodline on 0345 988 1188 to register for a flood warning, or visit <https://www.gov.uk/sign-up-for-flood-warnings>. It's a free service that provides warnings of flooding from rivers, the sea and groundwater, direct by telephone, email or text message. Anyone can sign up.

Flood warnings can give people valuable time to prepare for flooding – time that allows them to move themselves, their families and precious items to safety. Flood warnings can also save lives and enable the emergency services to prepare and help communities.

For practical advice on preparing for a flood, visit <https://www.gov.uk/prepare-for-flooding>.

To get help during a flood, visit <https://www.gov.uk/help-during-flood>.

For advice on what to do after a flood, visit <https://www.gov.uk/after-flood>.

Please do not hesitate to contact me using the contact details shown below should you have any queries regarding the above information.

Yours faithfully

Mrs Sophie Brown
Sustainable Places Planning Advisor

Direct dial 02030 257250

Direct e-mail planningSSD@environment-agency.gov.uk