

# Consultee Comments for Planning Application APP/21/00969

## Application Summary

Application Number: APP/21/00969

Address: 322 Sea Front, Hayling Island, PO11 0AZ

Proposal: Single storey rear extension to the main house and replacement of existing annexe to provide single storey accommodation, with associated external works.

Case Officer: Julie Terzoudis

## Consultee Details

Name: Mrs Sally Nixon Building Control Team

Address: Public Service Plaza, Civic Centre Road, Havant PO9 2AX

Email: bct@havant.gov.uk

On Behalf Of: Building Control

## Comments

East elevation wall of the annex to be 30 minutes fire resistant due to the distance to the boundary.