

Good Morning David,

Thankyou for your email. To clarify our position Portsmouth Water agrees to the discharge of Condition 11 subject to further information to be submitted, reviewed and agreed with the Catchment Management Team in regard to the verification reports under Condition 12.

We can also confirm that Portsmouth Water agrees Condition 17 may be discharged on the basis the maximum depth of piles will be 17mbgl - allowing a minimum of 3 meters buffer between their maximum terminating depth and the underlying confined chalk aquifer. Should the piles exceed 17 meters in depth we would wish to be consulted further.

Kind Regards

**Catchment Management Team**

*Portsmouth Water*

Email: [catchment.management@portsmouthwater.co.uk](mailto:catchment.management@portsmouthwater.co.uk)

Address: Portsmouth Water Ltd, Po Box 99 West Street, Havant, PO9 1LG