



Department of Planning and
Development
Havant Borough Council
Public Service Plaza
Civic Centre Road
Havant
Hampshire
PO9 2AX



Developer Services
Southern Water
Southern House
Sparrowgrove
Otterbourne
Hampshire
SO21 2SW

Tel: 0330 303 0119

Email: developerservices@southernwater.co.uk

Your Ref
APP/15/00686

Our Ref
PLAN-011205
Date

17/09/2015

Dear Sirs,

**Proposal: Discharge of Condition No's. 2,3,4,5,7,19 of Planning Permission
APP/12/01233.**

**Site: Former site of St Andrews House, 59-61 West Street, Havant, PO9 1LB.
APP/15/00686**

Further to your letter of 02/07/2015 and further discussions with the applicant, please note that Southern Water would have no objections to discharge condition 2 relating to foul drainage.

The adoptable sewers will have to comply with Sewers for Adoption standards. If the drainage is proposed for adoption by sewerage undertaker, a formal section 104 sewer adoption application is required to be submitted and approved by Southern Water Services before a connection to the public sewer is made.

An application under Section 106 (connection) under the Water Industry Act needs to be submitted and approved by Southern Water.

The Council's Building Control officers/technical staff and the Environment Agency should be consulted regarding the surface water disposal.

Yours sincerely



Developer Services