



Hampshire County Council

*Economy, Transport and Environment Department
Elizabeth II Court West, The Castle
Winchester, Hampshire SO23 8UD*

Tel: 0300 555 1375 (General Enquiries)
0300 555 1388 (Roads and Transport)
0300 555 1389 (Recycling Waste & Planning)
Textphone 0300 555 1390
Fax 01962 847055
www.hants.gov.uk

<i>Enquiries to</i>	Santiago Manzanero	<i>My reference</i>	SWM/2021/0150
<i>Direct Line</i>	01962 846777	<i>Your reference</i>	APP/2021/0150
<i>Date</i>	21 October 2021	<i>Email</i>	SWM.consultee@hants.gov.uk

Dear Sir/Madam,

Variation of Condition B6 of Planning Permission APP/15/00732 to remove restriction on proportion of B8 floorspace allowed within the Dunsbury Park development, and thus provide for a maximum mixed use floor space of 61,779sqm within Classes B1, B2 and/or B8 of the Use Classes Order 1987 as amended (13.12.18). Request to discharge conditions A3, A5, A10, A11, A12 & 13, A14, A17 & 18 and B10 (03.12.20). at Dunsbury Park, Fitzwygram Way, Havant, PO9 4EE.

Hampshire County Council as Lead Local Flood Authority has provided comments in relation to the above application in our role as statutory consultee on surface water drainage for major developments.

In order to assist applicants in providing the correct information to their Local Planning Authority for planning permission, Hampshire County Council has set out the information it requires to provide a substantive response at <https://www.hants.gov.uk/landplanningandenvironment/environment/flooding/planning>

The County Council has reviewed the following documents relating to the above application:

- Below Ground Drainage, Initial Design Concept; drg no: 4330 Z4A-U; dated: 25th May 2021.
- Below Ground Drainage Strategy Sheet 1; ref: DHF-BMD-ZZ-ZZ-DR-D-59000-C09; dated: October 2020.

Following our formal response to this planning application dated 10th March 2021, we received additional information on the 07th October 2021 including the wider attenuation ponds details and requested hydraulic calculations.

Director of Economy, Transport and Environment
Stuart Jarvis BSc DipTP FCIHT MRTPI

The additional information has addressed our concerns regarding surface water management and local flood risk. Therefore, the County Council as the Lead Local Flood Authority would have **no objection** for condition A3 and B10 of planning application APP/17/01324 to be discharged.

We have no comments to make on other planning conditions.

As a statutory consultee, the County Council has a duty to respond to consultations within **21 days**. The 21 day period will not begin until we have received sufficient information to enable us to provide a meaningful response.

Please ensure all data is sent to us via the relevant Local Planning Authority.

For guidance on providing the correct information, we recommend you use our **Surface Water Management Pre-application service** which provides clear guidance on what is required for us to recommend that planning permission is granted and consider the works as best practise. For full details, please visit: <https://www.hants.gov.uk/landplanningandenvironment/environment/flooding/planning> and click on [pre-application advice request form](#).

This response has been provided using the best knowledge and information submitted as part of the planning application at the time of responding and is reliant on the accuracy of that information.

Yours faithfully,



Flood and Water Management Team
Economy, Transport & Environment Department,
Hampshire County Council, 1st Floor, Ell Court West,
The Castle, Winchester, Hampshire SO23 8UD
Web: <https://www.hants.gov.uk/landplanningandenvironment/environment/flooding>

General guidance for the application

It is important to ensure that the long-term maintenance and responsibility for Sustainable Drainage Systems is agreed between the Local Planning Authority and the applicant before planning permission is granted. This should involve discussions with those adopting and/or maintaining the proposed systems, which could include the Highway Authority, Planning Authority, Parish Councils, Water Companies and private management companies.

For SuDS systems to be adopted by Hampshire Highways it is recommended that you visit the website at:

<https://www.hants.gov.uk/transport/developers/constructionstandards> for guidance on which drainage features would be suitable for adoption.

Where the proposals are connecting to an existing drainage system it is likely that the authorities responsible for maintaining those systems will have their own design requirements. These requirements will need to be reviewed and agreed as part of any surface water drainage scheme.

Works in relation to ordinary watercourses

*PLEASE NOTE: If the proposals include works to an ordinary watercourse, under the Land Drainage Act 1991, as amended by the Flood and Water Management Act 2010, prior consent from the Lead Local Flood Authority is required. **This consent is required as a separate permission to planning.***

Information on ordinary watercourse consenting can be found at the following link

<https://www.hants.gov.uk/landplanningandenvironment/environment/flooding/c/hangewatercourse>

It is strongly recommended that this information is reviewed before Land Drainage consent application is made.

*For guidance on providing the correct information, we recommend you use our **Ordinary Watercourse Consents Pre-application service** and help avoid delays occurring at the formal application stage. A Pre-application service for Ordinary Watercourse Consents is available, allowing consents to go through in a smoother, often more timely manner. For full information please visit:*

<https://www.hants.gov.uk/landplanningandenvironment/environment/flooding/c/hangewatercourse>