

Registered Office:
Portsmouth Water Ltd
PO Box 8
Havant
Hampshire PO9 1LG

Tel: 023 9249 9888
Fax: 023 9245 3632
Web: www.portsmouthwater.co.uk

**CONSULTATION UNDER THE TOWN AND COUNTRY PLANNING
(DEVELOPMENT MANAGEMENT PROCEDURE ENGLAND) ORDER 2015**

Planning Application Reference:	APP/20/00913
Proposal:	Demolition of existing buildings in a conservation area and erection of 2 No. 3 bed houses, 1 No. 1 bed apartment and 1 No. 2 bed maisonette. Request to discharge conditions 4, 5, 6, 7, 12, 14 and 16 (30/11/2021).
Location:	10A The Pallant, Havant, PO9 1BE
Date:	19 January 2022

Portsmouth Water have reviewed the further documentation to support the discharge of condition 14 of planning permission APP/20/00913.

Condition 14- Piling

The proposed piling method for the development is CFA piling; this is the preferred approach to piling in relation to groundwater protection. The maximum depth of the piles (13.5m) will terminate in the clay cover and the confined chalk will not be breached. We therefore have no objections to the discharge of Condition 14.

Catchment Management Team
Portsmouth Water

catchment.management@portsmouthwater.co.uk