

From: Richards, Gemma <Gemma.Richards@easthants.gov.uk>

Sent: 17 February 2022 10:09

To: Eaves, David <David.Eaves@havant.gov.uk>

Subject: APP/19/00007 - Discharge of conditions 26, 28 and 30 - Camp Field (land to the west of Havant Crematorium), Bartons Road, Havant

Hi David

I refer to the consultation we have received for the discharge of conditions 26 (Construction Management Plan), 28 (Construction Environmental Management Plan) and 30 (Piling) of the above approval.

The sections of conditions 26 and 28 that relate to environmental matters can be approved, however no information has been provided in the Piling Method Statement on the measures that will be taken to reduce noise impacts to the adjacent crematorium and nearby residential properties which means condition 30 should not be discharged at this time. There is no information on predicted noise levels at sensitive receptors, a plan of the layout of the proposed piling, how long the activity will take place onsite or noise protection measures that will be used. The crematorium is a highly sensitive premises and the developer will have to work with them to find a suitable solution to ensure that services are not adversely impacted by noise.

Please do not hesitate to contact me if you have any queries.

Regards

Gemma

Gemma Richards

Pollution Team Leader | T: 01730 234322

Environmental Health

Havant Borough Council, Public Service Plaza, Havant, PO9 2AX

East Hampshire District Council, Penns Place, Petersfield, GU31 4EX