

From: Adcock, Charlotte <charlotte.adcock@easthants.gov.uk>
Sent: 13 July 2021 15:55
To: Harvey, Paige <Paige.Harvey@havant.gov.uk>
Subject: RE: APP/21/00545 - 40 Rowlands Avenue

Hello Paige

Sorry for the delay in replying to this application.

My concerns with respect to this application simply relates to any mechanical plant and equipment used as part of this installation and associated noise, also any additional lighting used on the outside of the building .

The details mention that there may be a requirement for extract ventilation to control humidity levels in the room as well as the pump equipment for heating and circulating the pool water.

I would like to request an acoustic report be submitted to the LPA for approval, which uses the BS4142 assessment methodology to demonstrate that operation of the pool mechanical plant and equipment will not give rise to disturbance to neighbours as a result of noise emitted from the plant . Lighting might also give rise to complaint if it used outside, and so I would also ask that details of lighting to be included as part of this installation, be submitted to this Authority for prior approval.

Thanks and regards

Charlotte Adcock – Pollution Team Leader
East Hampshire District Council
Penns Place, Petersfield GU31 4EX
Direct Tel: 01730 234402

www.easthants.gov.uk
www.facebook.com/EastHampshireDistrictCouncil
www.twitter.com/EastHantsDC

Your privacy matters, go to www.easthants.gov.uk/privacy-policy

Charlotte Adcock – Pollution Team Leader
Havant Borough Council
Public Service Plaza, Civic Centre
Direct Tel: 01730 234402

www.havant.gov.uk
www.facebook.com/havantborough
www.twitter.com/havantborough

Your privacy matters, go to www.havant.gov.uk/privacy-policy