



Hampshire County Council

*Economy, Transport and Environment Department
Elizabeth II Court West, The Castle
Winchester, Hampshire SO23 8UD*

Tel: 0300 555 1375 (General Enquiries)
0300 555 1388 (Roads and Transport)
0300 555 1389 (Recycling Waste & Planning)
Textphone 0300 555 1390
Fax 01962 847055
www.hants.gov.uk

<i>Enquiries to</i>	Santiago Manzanero	<i>My reference</i>	SWM/2021/0663
<i>Direct Line</i>	0370 779 8301	<i>Your reference</i>	APP/21/00931
<i>Date</i>	3 November 2021	<i>Email</i>	SWM.consultee@hants.gov.uk

Dear Sir/Madam,

Outline application for demolition of the existing buildings and development of the site to provide 31 homes with associated parking, access and landscaping. at Dairy Crest Depot, Dunsbury Way, Havant.

Hampshire County Council as Lead Local Flood Authority has provided comments in relation to the above application in our role as statutory consultee on surface water drainage for major developments.

In order to assist applicants in providing the correct information to their Local Planning Authority for planning permission, Hampshire County Council has set out the information it requires to provide a substantive response at <https://www.hants.gov.uk/landplanningandenvironment/environment/flooding/planning>

The County Council has reviewed the following documents relating to the above application:

- FLOOD RISK ASSESSMENT AND DRAINAGE STRATEGY;
DOCUMENT REFERENCE: 5016160-RDG-XX-XX-DOC-C-9900; REV:
1.0; dated: 02/09/2021.

The Information submitted by the applicant in support of this planning application indicates that surface water runoff from the application site will be managed through permeable paving. Additionally, surface water will be discharged, at a discharge rate of 2.6 l/s, into the surface water public sewer network at Dunsbury Road.

The proposals are acceptable in principle since that the underlying geology will make infiltration infeasible at the application site, and considering that the

Director of Economy, Transport and Environment
Stuart Jarvis BSc DipTP FCIHT MRTPI

applicant is proposing a betterment over the existing discharge rates into the public sewer network.

While the information submitted indicates that: "the redevelopment of the former Dairy Crest Depot site currently has foul and surface water discharge to a sewer", the proposals include a new connection to the sewer network and there is no information within the planning website which demonstrates that the asset owner has agreed to the proposed discharge rate and connection. Failure to secure this agreement is likely to necessitate in the need to review the drainage proposals for the application, which may have implications for the drainage proposals, proposed quantum and layout of the proposed development.

The information submitted by the applicant has addressed our concerns regarding surface water management and local flood risk. Therefore, the County Council as the Led Local Flood Authority has **no objection** to the proposals subject to the following planning conditions:

1. The drainage system shall be constructed in accordance with the Flood Risk Assessment and Drainage Strategy ref: 5016160-RDG-XX-XX-DOC-C-9900. Surface water discharge to the public sewer network shall be limited to 2.6 l/s. Any changes to the approved documentation must be submitted to and approved in writing by Local Planning Authority and Lead Local Flood Authority. Any revised details submitted for approval must include a technical summary highlighting any changes, updated detailed drainage drawings and detailed drainage calculations.
2. Evidence that Southern Water has agreed to the proposed discharge rate and connection should be submitted before any connection is made. The condition of the existing sewer, which will take surface water from the development site, should be investigated before any connection is made. If necessary, improvement to its condition as reparation, remediation, restitution and replacement should be undertaken. Evidence of this, including photographs should be submitted.
3. Details for the long-term maintenance arrangements for the surface water drainage system shall be submitted to and approved in writing by the Local Planning Authority prior to the first occupation of any of the dwellings. The submitted details shall include:
 - a. Maintenance schedules for each drainage feature type and ownership
 - b. Details of protection measures.

As a statutory consultee, the County Council has a duty to respond to consultations within **21 days**. The 21 day period will not begin until we have received sufficient information to enable us to provide a meaningful response.

Please ensure all data is sent to us via the relevant Local Planning Authority.

For guidance on providing the correct information, we recommend you use our **Surface Water Management Pre-application service** which provides clear guidance on what is required for us to recommend that planning permission is granted and consider the works as best practise. For full details, please visit: <https://www.hants.gov.uk/landplanningandenvironment/environment/flooding/planning> and click on [pre-application advice request form](#).

This response has been provided using the best knowledge and information submitted as part of the planning application at the time of responding and is reliant on the accuracy of that information.

Yours faithfully,

A handwritten signature in black ink, appearing to be 'PP' followed by a stylized name.

Flood and Water Management Team
Economy, Transport & Environment Department,
Hampshire County Council, 1st Floor, EII Court West,
The Castle, Winchester, Hampshire SO23 8UD
Web: <https://www.hants.gov.uk/landplanningandenvironment/environment/flooding>

General guidance for the application

It is important to ensure that the long-term maintenance and responsibility for Sustainable Drainage Systems is agreed between the Local Planning Authority and the applicant before planning permission is granted. This should involve discussions with those adopting and/or maintaining the proposed systems, which could include the Highway Authority, Planning Authority, Parish Councils, Water Companies and private management companies.

For SuDS systems to be adopted by Hampshire Highways it is recommended that you visit the website at:

<https://www.hants.gov.uk/transport/developers/constructionstandards> for guidance on which drainage features would be suitable for adoption.

Where the proposals are connecting to an existing drainage system it is likely that the authorities responsible for maintaining those systems will have their own design requirements. These requirements will need to be reviewed and agreed as part of any surface water drainage scheme.

Works in relation to ordinary watercourses

*PLEASE NOTE: If the proposals include works to an ordinary watercourse, under the Land Drainage Act 1991, as amended by the Flood and Water Management Act 2010, prior consent from the Lead Local Flood Authority is required. **This consent is required as a separate permission to planning.***

Information on ordinary watercourse consenting can be found at the following link

<https://www.hants.gov.uk/landplanningandenvironment/environment/flooding/c/hangewatercourse>

It is strongly recommended that this information is reviewed before Land Drainage consent application is made.

*For guidance on providing the correct information, we recommend you use our **Ordinary Watercourse Consents Pre-application service** and help avoid delays occurring at the formal application stage. A Pre-application service for Ordinary Watercourse Consents is available, allowing consents to go through in a smoother, often more timely manner. For full information please visit:*

<https://www.hants.gov.uk/landplanningandenvironment/environment/flooding/c/hangewatercourse>