

Havant Towers Car Park Lighting and CCTV

Hi Michael,

Further to our discussion. I can confirm the scheme meets the standard BS12464 of an average minimum of 5lux and a minimum uniformity of 0.25.

I trust the above meets with your approval and if you require anymore information please do not hesitate to contact me.

Kind Regards

Liam Parkinson

Lighting Design Engineer

Steon Lighting



**STEON ARE CELEBRATING 50 YEARS TRADING
WITHIN THE LIGHTING INDUSTRY**



Steon Ltd, Bridgewater Court, Network 65 Business Park,
Burnley, Lancashire, BB11 5ST



www.steon.com



01282 448666

07903 231471

This is an email from Steon Ltd. Its contents are confidential and are intended solely for the addressee. It may not be copied, disclosed to or used by anyone other than its addressee. If received in error, please contact Steon Ltd. on +44 (0) 1282 448666 quoting the name of the sender and the addressee, then delete it from your system.

Please note that neither Steon Ltd. nor the sender accepts any responsibility for viruses and it is your responsibility to scan attachments (if any).