

HAVANT BOROUGH COUNCIL

Town & Country Planning Act 1990

Consultation on Planning Application

MEMORANDUM

From:	Environmental Health	To:	Development Control
Our Ref:	CONS/16/01502	Your Ref:	APP/16/00952
EH Case Officer Extn:	44 6671	Date:	24 October 2016
DC Case Officer:	Heather Lealan		
DC Case Officer Extn:	44 6523		
Application Number:	APP/16/00952		
Site Address:	Blendworth Common, Havant Road, Horndean, Waterlooville		
Proposed Development:	Construction and operation of a 20MW Peaking Power Generation Plant, Ancillary Equipment and Access.		

I attach a copy of the above application that has been received under the Town and Country Planning Acts.
Any views you should wish to make should be returned to me no later than 04/11/2016.

Observations / Comments:

Good morning Heather,
I have been asked to comment on this application.
I have read the information provided by the applicant.

The acoustic report provided by Inacoustic appears sound and as long as the mitigation measures are built to the recommendation, I should have no comment to make.
I would like however to be advised if noise levels could be obtained from already operating sites, with the same or similar equipment that the company or industry have, this to ensure that the numbers used are within the ball park of the assumption and derivations.

I have read that the path to the site will be constructed using a "no dig" construction, thus minimising the impact on the land and wildlife etc... and I am assuming from the statement that this will also prevent any dust from being created during the construction phase and thereafter the operational phase, when trucks/maintenance occurs at the site?. Would you be able to confirm this? further, I am assuming that the equipment will all be surface mounted/operated and no ground levelling, burying of cables/pipe will take place which may create dust?

Please do not hesitate to contact me if you have any queries.
Kind regards
Laurent

Mr. Laurent Lemagnen
Senior Environmental Health Officer