

Havant Borough Council
Civic Offices
Civic Centre Road
Havant
PO9 2AX

*Economy, Transport and Environment Department
Elizabeth II Court West, The Castle
Winchester, Hampshire SO23 8UD*

Tel: 0300 555 1375 (General Enquiries)
0300 555 1388 (Roads and Transport)
0300 555 1389 (Recycling Waste & Planning)
Textphone 0300 555 1390
Fax 01962 847055
www.hants.gov.uk

Enquiries To Sophie Osborne

Direct Line 0370 779 5232

Date 15 September 2021

My reference 0033656

Your reference APP/21/00953

Email havantdc@hants.gov.uk

Dear Sir,

23 Park Avenue, Waterloo, PO7 5DN

Single storey rear extension, porch canopy, vehicular access from Park Avenue and parking.

Thank you for consulting the Highway Authority on the above planning application. The Highway Authority wish to make the following comments.

The applicant is proposing a single storey rear extension, porch canopy and a new vehicular access to the property from Park Avenue.

The Highway Authority will require a diagram showing the length of the proposed new drop kerb along with visibility splays for this new access. For further information on visibility splays please see the Hampshire County Council Technical Guidance TG3 using the following link: [Microsoft Word - TG3 Technical Guidance Note - Stopping Sight Distances and Visibility Splays \(A1001001A17F05B10508J50123\)1.docx \(hants.gov.uk\)](#)

Additionally, it is recommended to the applicant that they should be made aware that subject to any planning permission being granted by the Local Planning Authority, a subsequent agreement will need to be granted by HCC as Highway Authority to undertake the drop kerb works on the Highway. Details of this procedure can be found via the following link: [Apply for a vehicular access | Hampshire County Council \(hants.gov.uk\)](#). It is important to note that if there are any minor utility diversions that

*Director of Economy, Transport and Environment
Stuart Jarvis BSc DipTP FCIHT MRTPI*

are required to facilitate the dropped kerb then additional costs may arise in addition to the initial application fee. The applicant should also be aware that if an existing access is to be closed, a full height kerb should be reinstalled.

Whilst the Highway Authority can confirm that the above planning application will not have a detrimental impact on the wider highway network, the Highway Authority require the additional information requested before a formal recommendation can be made.

Yours faithfully,

Sophie Osborne

Assistant Transport Planner – Highways Development Planning

Director of Economy, Transport and Environment
Stuart Jarvis BSc DipTP FCIHT MRTPI