

Consultee Comments for Planning Application APP/13/00804

Application Summary

Application Number: APP/13/00804

Address: Woodcroft Farm Development Site, Woodcroft Lane, Waterlooville

Proposal: Development of 288 residential units comprising 9 x one bedroom, 110 x two bedroom, 124 x three bedroom and 45 x four bedroom, retention of existing farmhouse, new access road from Eagle Avenue, internal access roads, associated car parking, open space and landscaping and including works to trees under TPO 1931 (Approved 5 May 2015). Request to discharge condition 26 and partially discharge condition 5 (3.1.17). Request to Discharge Condition No.s 2, 3, 6 and 8 (21.02.17). Request to partially discharge condition 19 (28.2.17). Request to discharge condition No. 2 (24.08.17). Request to Discharge Condition Nos. 2 and 5 (21.02.18). Request to discharge conditions 3, 4, 6, 7, 8, 9, 10, 11, 12, 14, 15, 16, 17, 18, 19, 25, 29, 30, 31 and 33 (3.04.18). Request to Discharge Condition No/s 3, 4, 6, 7, 8, 9, 10, 11, 12, 14, 16, 17 & 18 (Residential Phase 2) (06.06.2019). Request to Discharge Conditions 15 and 30 (02/08/2019). Request to Discharge Conditions 7,9 & 10 (Phase 2) (21.07.20). Request to Discharge Conditions 5 and 6 (31.07.20). Request to Discharge Conditions 3, 4, 8, 14, 16, 17 (25.08.20). Request to Discharge Condition 15 (02.09.20). Request to discharge condition 31 (06.11.20). Request to partially Discharge Condition 11 (30.11.2020). Request to discharge condition No. 9 (16.02.2021). Request to discharge condition No. 31 (Phase 2B) (08.03.2021). Request to discharge condition No. 25 (Phase 2B & 3 (Residential Phase 1A & 2)) (08.03.2021). Request to discharge condition 9 (Phase 2) (29.03.21). Request to discharge condition No's 22 and 32 (23.04.2021).

Case Officer: Paige Harvey

Consultee Details

Name: Consultee Landscape Architect

Address: Public Service Plaza, Civic Centre Road, Havant PO9 2AX

Email: harry.mitchell@havant.gov.uk

On Behalf Of: Landscape Team, Havant Borough Council

Comments

Planning Application APP/13/00804 Woodcroft Farm Development Site, Woodcroft Lane, Waterlooville

Request to discharge condition No's 22 and 32 (23.04.2021).

From a landscape perspective we have the following comments in relation to this discharge of conditions no. 22 and 32:

Condition 32 The Oak trees are seem very closely planted and given the ample space available it would be better for the tree canopy to space them out. Oaks can have a canopy spread of over

8m+ when mature so allowing sufficient space to grow needs to be considered.

Condition 22 No adverse comments recommend to discharge condition no. 22.

Kind regards,

Harry Mitchell CMLI
Chartered Landscape Architect
Havant Borough Council