

Consultee Comments for Planning Application APP/21/01242

Application Summary

Application Number: APP/21/01242

Address: 23 Winterslow Drive, Havant, PO9 5DX

Proposal: Two storey side extension to create a new 1 bedroom dwelling. (Revision to Planning Permission APP/17/00380).

Case Officer: Lesley Wells

Consultee Details

Name: Mrs Sally Nixon Building Control Team

Address: Public Service Plaza, Civic Centre Road, Havant PO9 2AX

Email: bct@havant.gov.uk

On Behalf Of: Building Control

Comments

Building Regulation consent required

First floor bedroom is an inner room MOE window need 0.33msq clear opening