

Registered Office:
Portsmouth Water Ltd
PO Box 8
Havant
Hampshire PO9 1LG

Tel: 023 9249 9888
Fax: 023 9245 3632
Web: www.portsmouthwater.co.uk

**CONSULTATION UNDER THE TOWN AND COUNTRY PLANNING
(DEVELOPMENT MANAGEMENT PROCEDURE ENGLAND) ORDER 2015**

Planning Application Reference:	APP/18/00478
Proposal:	Application for variation of Condition 15 of Planning Permission APP/15/01233 relating to internal layout, fenestration layout and main entrance (approved 16.8.18). Request to discharge condition No. 6 (3.09.18). Request to discharge condition No's 3, 4, 9, 11 and 14 (10.09.18). Request to discharge condition No. 6 (22.04.2021).
Location:	Land adjacent to Fulflood Road, Havant
Date:	25 June 2021

Portsmouth Water have reviewed the documentation to support the discharge of condition 6.

Condition 6- Land Contamination Risk Assessment

Portsmouth Water have reviewed the Interpretive Report on Ground Investigation by Structural Soils Ltd. Portsmouth Water agree with the conceptual model provided and the linkage assessment. The site will be surfaced with impermeable finishes which will prevent infiltration of leachate in addition surface water is to be attenuated prior to final discharge. The linkage for leaching contaminants from the unsaturated zone to groundwater in the Secondary A Aquifer is incomplete and therefore we have no objection to the discharge of Condition 6 from a groundwater quality protection perspective.

Catchment Management Team
Portsmouth Water

catchment.management@portsmouthwater.co.uk