

Mr D Shepherd
5-7 Station Road
Hayling Island

Our Ref: APP/19/00324
Direct Line: (023) 02392 446530
Ask For: Paige Harvey
Email: planning.development@havant.gov.uk
18 August 2021

**Town and Country Planning (Development Management Procedure) (England) Order 2015
Discharge of Conditions Application**

Application Number: APP/19/00324

Site Address: 5-7 Station Road, Hayling Island

Description: Demolition of existing dwelling and business units and construction of a 2/3 storey building to provide 19 flats and 2 commercial units with vehicle and bicycle parking and a bin store (11.2.21). Request to discharge condition 4 (4.3.21). Request to discharge conditions 9, 10, 11, 12, 13, 14, & 15 (27.04.21). Request to discharge condition No/s 5 and 7 (28.06.2021).

This decision relates to your request to discharge conditions which was valid from 28/06/2021.

Havant Borough Council as Local Planning Authority hereby APPROVES the submitted application as meeting the information requirements of the following Conditions of Planning Permission APP/19/00324.

The condition in respect of which information has been submitted is:

Condition 7:

No development shall begin until a detailed surface water drainage scheme for the site, based on the principles outlined under planning reference APP/19/00324, has been submitted and approved in writing by the Local Planning Authority. The submitted details shall include:

- a. A technical summary highlighting any changes to the design from that within the approved documentation submitted under APP/19/00324;
- b. Detailed drainage plans to include type, layout and dimensions of drainage features including references to link to the drainage calculations;
- c. Detailed drainage calculations to demonstrate existing runoff rates are not exceeded and there is sufficient attenuation for storm events up to and including 1:100 + climate change; and
- d. Exceedance plans demonstrating the flow paths and areas of ponding in the event of blockages or storms exceeding design criteria.

The development shall thereafter be carried strictly in accordance with the approved scheme.

Reason: To safeguard the amenities of the locality and ensure that all drainage provision is constructed to an appropriate standard and quality and having due regard to Policies CS15, CS16 and DM10 of the Havant Borough Local Plan (Core Strategy) 2011 and the National Planning Policy Framework.

Details submitted:

Drainage General Arrangement 414406-100P7

Drainage Report 22/6/21

Plot Report

Reasons for approval

The details hereby approved are considered to be in accordance with the relevant adopted policies of the Council, in particular the policies contained within the Havant Borough Local Plan (Core Strategy) 2011.

- (1) This notice only relates to the decision of Havant Borough Council as Local Planning Authority under the Town and Country Planning Acts. It does not relate to any other application that may be required under the Building Regulations or under any other Act, Regulation, Byelaw or Order where the Council's approval may be needed. For further guidance as to the need for consent under the Building Regulations please phone 023 9244 6573.
- (2) Any failure to adhere to the details of the approved plans, and other documents or to comply with any conditions listed above may lead to enforcement action being taken by the Council. If you wish to depart from the approved details or conditions in any way you should contact the Planning Development Service at the Public Service Plaza or by telephoning 023 9244 6015.

Simon Jenkins

Simon Jenkins

Director of Regeneration and Place

Date: 18 August 2021