

# Consultee Comments for Planning Application APP/16/01077

## Application Summary

Application Number: APP/16/01077

Address: Eastleigh House, Bartons Road, Havant, PO9 5NA

Proposal: Residential development to provide 10 dwellinghouses along with the continued use of Eastleigh House as Class B1(a) offices and the demolition of outbuildings to the rear of the building.

Case Officer: Rachael McMurray

## Consultee Details

Name: Mrs Sally Building Control Team

Address: Public Service Plaza, Civic Centre Road, Havant PO9 2AX

Email: bct@havant.gov.uk

On Behalf Of: Building Control

## Comments

Solid waste bin storage shown on plan but unable to scale. Max. carry to bin by householder is 30m to comply with Approved Document H

Fire Authority access onto block paving area should be designed to carry suitable load

Trees shown on access road should provide headroom clearance to comply with Approved Document B5