

Hi Simon

Apologies for the delay in responding.

As per our discussion, it is felt that the information now provided should suffice:

- Only one unit, a Delta 4 is to be sited within the plant room
- The fans will be operating 24 hours per day
- It will be fitted with 1200 (assume mm) attenuators to the fresh air inlet & exhaust outlet to the external wall louvres (vents) which will give a noise reading (NR) of 30 – 35 dB at 3 metre distance from the louvres
- The integral insulation measures to the plant room fabric should further assist to inhibit noise escape from this room
- The filtration units are built into the pool structure

Broadly speaking the measures advised to be implemented, should be enough to prevent any noise nuisance from the above mentioned equipment from impacting on the nearest residential receptors.

However should we happen to receive any noise complaints in the future, related to any of the above equipment, we will deal with these at that time.

I would suggest that you can now discharge this condition.

Kind regards

Mark Moss

Senior Regulatory Officer

Environmental Health

Havant Borough Council, Public Service Plaza, Civic Centre Road, Havant PO9 2AX

Tel: 02392 - 446666 or Admin support: 02392-446670