WARNING! This area contains Gas Mains operating at High Pressure in excess of 7 bar. Before excavating in the area contact the local network office.

SU2206NE
SU2206NW
SU2206SE
SU2206SW
SU7306NE
SU7406NW
SU7306SW
SU7306SE
SU7406SW
SU7305NW
SU7305NE

SEE SKETCH PO14/GE05/B

22.5 DEG SB
CP POST
45 DEG SB
11.25 DEG SB
NITROGEN SLEEVE

Before Excavation
P18 Procedure Applies

PORTSDOWN HILL-APULDRAM
400 ST H/P
PO14 231300060

4" SI
63 PE
4" DI
125 PE
12" CI
300 DI
250 PE
2 X 280 PE IN 2 X 309mm DUCTS
4" CI
6" SL
2" SI
1.5" CI
90 PE (IN 4" CI)
72 PE (IN 4" CI)
50 PE (IN 2" ST)
63 PE (IN 4" CI)

Site Fed By Other GT
GTC Pipelines Ltd
GT Ref: N9002360
SGN Ref: P05119737

D 237
D209
DOC 0.7
650E92335

WARBLINGTON REGULATOR
Area assigned to Mayflower: Ref 931660
P092
WARBLINGTON TO WARBLINGTON TEE
234300010
16" ST M/P
B.G. SOUTHERN VALVE (WRBT)

0 30 Meters

SCALE 1: 927

USER ID: lm67730

DATE: 11/08/2016

INTERNAL USE ONLY

GRID REFERNCE:
E473500,N106229,SU 73 06

LP MAINS
MP MAINS
IP MAINS
LHP MAINS
HISTORY DATA
LAs
GTs
SSSIs

Some examples of Plant items:
Valve
Depth of Cover
Syphon
Diameter Change
Material Change

This plan shows the location of those pipes owned by Scotia Gas Networks (SGN) by virtue of being a licensed Gas Transporter (GT). Gas pipes owned by other GTs or third parties may also be present in this area but are not shown on this plan. Information with regard to such pipes should be obtained from the relevant owners. No warranties are given with regard to the accuracy of the information shown on this plan. Service pipes, valves, siphons, sub-connections etc are not shown but their presence should be anticipated. You should be aware that a small percentage of our pipes/assets may be undergoing review and will temporarily be highlighted in yellow. If your proposed works are close to one of these pipes, you should contact the SGN Plant Protection Team on 08450703497 for advice. No liability of any kind whatsoever is accepted by SGN or its agents, servants or sub-contractors for any error or omission contained herein. Safe digging practices, in accordance with HS (G)47, must be used to verify and establish the actual position of mains, pipes, services and other apparatus on site before any mechanical plant is used. It is your responsibility to ensure that plant location information is provided to all persons (whether direct labour or sub-contractors) working for you on or near gas apparatus. Information included on this plan should not be referred to beyond a period of 28 days from the date of issue.

INTRANET MAP VERSION 2.1

Hampshire County Area

This plan is reproduced from or based on the OS map by Scotia Gas Networks plc, with the sanction of the controller of HM Stationery Office.Crown Copyright Reserved.

Scotia Gas Networks plc