

From: Peter Marshall
Sent: 02 December 2015 09:18
To: David Eaves
Subject: FW: Rear of 60-62 Hazleton Way APP/15/01286

Formal Response.

The Highway Authority has no adverse comment on this application providing the that existing access to Hart Plain Avenue and the servicing area can be included within the application and its use linked to the occupation of the flats

The Planning Authority is advised that the developer seeks to erect 4 new flats, consisting of 3No. 1 bed flats, and 1

No. 2 bed flat. The HBC standards are 1 parking space per one bed flat and 2 spaces for a two bed flats. I would suggest that developer should mark a plan with the location, of the 5 spaces associated with the development.

Peter J Marshall BSc MCIHT

Development Engineer
Havant Borough Council
Penner Road
Havant
Hants
PO9 1QH

Tel No. 02392446457
Email peter.marshall@havant.gov.uk
(My work days are Tuesday, Wednesday and Thursday)