

HAVANT BOROUGH COUNCIL

Town & Country Planning Act 1990

Consultation on Planning Application

MEMORANDUM

From:	Environmental Health	To:	Development Control
Our Ref:	CONS/16/01015	Your Ref:	APP/13/00765
EH Case Officer Extn:		Date:	10 August 2016
DC Case Officer:	Simon Kennedy		
DC Case Officer Extn:			
Application Number:	APP/13/00765		
Site Address:	Merok House Rest Home, 46 New Brighton Road, Emsworth, PO107QR		
Proposed Development:	Request to Discharge Condition 6 (12.07.2016). A request has been made to discharge the following condition(s) on the above application: Condition 6: No development shall take place until a scheme of external lighting has been submitted to and approved in writing by the local planning authority. Details shall include intensity and contours of illumination at neighbouring residential properties. Development shall be carried out in accordance with the approved details. There shall be no external lighting on the site other than as thereby approved. Any views you wish to make should be returned to me no later than 21 days from the date of this		

Observations / Comments:

Copndition 6:

I have read the e-mail from Stuart Bobe dd 1 August 2016, which confirms that all lights on the north elevation are to be positioned lower on the relevant wall to ensure to ensure that no light is emitted on a higher plane than the boundary wall.
based on this confirmation I am satisfied that this Condition can be discharged.

Mark Moss

Regulatory Officer, Environmental Health