

Consultee Comments for Planning Application APP/16/00252

Application Summary

Application Number: APP/16/00252

Address: 48 Station Road, Hayling Island, PO11 0EQ

Proposal: Proposed 1No. 3 bed dwelling. (Resubmission).

Case Officer: Rachael McMurray

Consultee Details

Name: Mrs Sally Building Control Team

Address: Public Service Plaza, Civic Centre Road, Havant PO9 2AX

Email: bct@havant.gov.uk

On Behalf Of: Building Control

Comments

If the construction of the dwelling is to be timber, 30 minutes fire resistance internally and externally will be required on the north and east elevations due to being close to the boundaries.