

Consultee Comments for Planning Application APP/16/00204

Application Summary

Application Number: APP/16/00204

Address: Latchmore House, 99-101 London Road, Cowplain, Waterlooville, PO8 8XJ

Proposal: Construction of mansard roof to form 2No. flats together with associated landscape scheme, cycle and refuse stores and alterations to car park. (Revised application).

Case Officer: Daphney Haywood

Consultee Details

Name: Mr Stephen Mountain

Address: 2 Penner Road, Havant PO9 1QH

Email: steve.mountain@havant.gov.uk

On Behalf Of: Engineering/Drainage, Havant Council

Comments

Is the intention for the foul pumping station to be maintained by the property owner? Otherwise it will need to be designed and constructed to meet requirements of SFA7. Note private pumping stations are being transferred to Southern Water and although those serving only one property are excluded at present, they can still be offered for adoption.