

Consultee Comments for Planning Application APP/16/00101

Application Summary

Application Number: APP/16/00101

Address: 52 Southleigh Road, Havant, PO9 2QH

Proposal: Plot severance and erection of 1No. 3 bedroom detached dwelling and 1No. 4 bedroom detached dwelling. Associated access and parking for both dwellings.

Case Officer: Daphney Haywood

Consultee Details

Name: Mrs Sally Building Control Team

Address: Public Service Plaza, Civic Centre Road, Havant PO9 2AX

Email: bct@havant.gov.uk

On Behalf Of: Building Control

Comments

Plot 1

1) Possible unprotected area issue on side elevation (lounge + ensuite windows) due to location of boundary

2) No solid waste storage shown

Plot 2

1) Possible Unprotected area issue with regards amount of glazing / opening facing side boundaries

2) No solid waste bin storage shown