

Department of Planning and
Development
Havant Borough Council
Public Service Plaza
Civic Centre Road
Havant
Hampshire
PO9 2AX

Developer Services
Southern Water
Sparrowgrove House
Sparrowgrove
Otterbourne
Hampshire
SO21 2SW

Tel: 0330 303 0119

Email: developerservices@southernwater.co.uk

Your Ref
APP/15/01147
Our Ref
PLAN-011642
Date
11/11/2015

Dear Sir

Proposal: Reserved Matters application for the erection of 1No. two storey dwelling for access, appearance, landscaping, layout and scale following Outline Permission APP/13/00039 together with Discharge of Conditions 7, 8, 9, 10, 11, 12, 13, 14, 15 and 16 relating to the outline permission.
Site: 7 North Close, Havant, PO9 2TE.
APP/15/01147

Thank you for your letter of 23/10/2015.


Southern Water would have no objections to discharge condition relating to foul drainage. Approval for the connection should be submitted under a section 106 connection application.

The Council's Building Control officers/technical staff and the Environment Agency should be consulted regarding the discharge condition for surface water disposal.

Please note no new tree planting should be located within 3 metres of the public sewer.

-No new soakaways should be located within 5 metres of a public sewer.

Yours sincerely


Developer Services

SOUTHERN WATER



The positions of pipes shown on this plan are believed to be correct, but Southern Water Services Ltd accept no responsibility in the event of inaccuracy. The actual positions should be determined on site.

Based upon Ordnance Survey Digital Data with the permission of the controller of H.M.S.O. Crown Copyright Reserved Licence No. WU 298530

O.S. REF: SU7205NW

Scale: 1:1250

Screen Print

WARNING: BAC pipes are constructed of Bonded Asbestos Cement

WARNING: Unknown (UNK) materials may include Bonded Asbestos Cement



Printed By: reddyma

Date: 3-11-2015

Southern Water MapGuide Browser

Requested By:

