



Mrs. E. Chisnall
Planning Services
Havant Borough Council
Public Service Plaza
Civic Centre Road
Havant
Hampshire
PO9 2AX

Date: 27th May 2016
Enquires to: Stuart York
Direct line: 023 8047 8566
Our reference: app/16
Your reference: APP/16/00437

Dear Mrs. Chisnall,

181 – 183 HAVANT ROAD, HAYLING ISLAND, PO11 0LG

Thank you for your letter of the 9th May 2016 and the opportunity to comment upon the application. Having considered the application I have the following comments to make with reference to crime prevention.

Automatic Teller Machines (ATMs) offer a range of opportunities for crime. With this application I have three main concerns:

- a. The safety of those using the ATM
- b. The safety of those replenishing the ATM
- c. The safety of the ATM itself

To provide for the safety of those using the ATM I recommend:

- a. An appropriate level of external lighting is installed
- b. Closed Circuit Television (CCTV) cameras are deployed to provide images of the ATM and the area about the ATM. The images should be of such quality so as to enable the identification of those present.

To provide for the safety of those replenishing the ATM I recommend:

- a. The rear of the ATM is within a store room, to prevent unauthorised access to the store (during replenishment operations) the access doors to this store should be third party certificated to LPS 1175 SR2
- b. CCTV cameras are deployed within the store room to provide coverage of the rear of the ATM
- c. A monitored intruder detector alarm is installed with panic buttons for use by those replenishing the ATM

To provide for the security of the ATM itself I recommend:

- a. The ATM is secured to the floor slab using a recognised fixing system, as outlined within the ATM Security Working Group Best Practice Guidance, there is no information relating to this in the documentation provided.
- b. The installation of a monitored intruder detector alarm with appropriate sensors to detect early signs of an attack to the ATM
- c. The plan shows bollards to the front of the ATM these bollards should be to PAS 68 standard.

If I can be of any further assistance please do not hesitate to contact me.

Yours sincerely,

S York
Crime Prevention Design Advisor

DISCLAIMER

This survey is based on information supplied by yourself and the current crime trends. I can only give a view on what measures might reduce the risk of crime and there can be no guarantee that the measures will prevent crime. The advice is given free with no intention of creating a contract. Neither the Home Office or the Police and Crime Commissioner for Hampshire take any other legal responsibility for the advice given.