

From: Michelle Good
Sent: 13 October 2016 16:58
To: Heather Lealan
Cc: Jamie Gargett
Subject: FW: Hayling Billy Pub, Elm Grove, Hayling Island - updated Arb submission


Afternoon,

Having reviewed the updated Tree Protection Plan (9030/02 Revision C), I note the provision for a new service corridor remote from root protection areas and the identified extents of 'no dig construction' for proposed paving within root protection areas.

Despite the drawing note mention of a piled foundation, there is no assurance elsewhere that this method will be utilised.

I remain concerned that conflicts between proposed drainage runs and tree protection areas have not been resolved by the updated Tree Protection Plan or the Method Statement.

The first extract below shows surface water and foul water drainage runs within the root protection area of T2 and T3.



The second extract below shows surface water drainage (including a manhole) within the root protection area of T7 and T8.

Kind Regards

Michelle Good CMLI

Senior Landscape Architect

Civil Engineering & Landscape Team

Telephone - 023 92446 537

Email - michelle.good@havant.gov.uk