

Consultee Comments for Planning Application APP/16/00073

Application Summary

Application Number: APP/16/00073

Address: 21 King Street, Emsworth, PO10 7AX

Proposal: Revised Application for proposed loft conversion including revised roof, rear dormer, proposed second floor gable window. Demolition of single-storey side lean-to and rear WC extension and erection of replacement single-storey side and rear extension. Revised fenestration.

Case Officer: Rachael McMurray

Consultee Details

Name: Mrs Sally Building Control Team

Address: Public Service Plaza, Civic Centre Road, Havant PO9 2AX

Email: bct@havant.gov.uk

On Behalf Of: Building Control

Comments

- 1) Glazing would appear excessive so SAP thermal calculation will be required
- 2) Structural calculations required for end wall as no returns adj doors re stability

No other comments

Colin

28-01-16