



EQUIPMENT SCHEDULE

Item	System Reference	Suffix	DWG	L1	L2/ID	W	H/Dia	Vol	PD	Wt		Performance, dB							
				mm	mm	mm	mm	m³/s	Pa	kg		63	125	250	500	1k	2k	4k	8k
1	SA 01 AHU01 SUPPLY	G	A02E	1200		650	600	1.19	24	68	IL	7	14	24	38	55	45	37	22
2	SA 02 AHU01 EXTRACT	G	A02E	1200		650	600	1	17	68	IL	7	14	24	38	55	45	37	22
3	SA 03 AHU01 INTAKE	G	A02E	1200		650	600	1	17	68	IL	7	14	24	38	55	45	37	22
4	SA 04 AHU01 EXHAUST	G	A02E	1200		650	600	1.19	24	68	IL	7	14	24	38	55	45	37	22
5	SA05 KITCHEN EXTRACT	GM1J	A02E	1500		700	700	0.98	24	100	IL	14	25	31	44	55	43	32	25
6	SA06 KITCHEN EXHAUST	GM1J	A02E	1500		700	700	0.98	24	100	IL	14	25	31	44	55	43	32	25
7	SA07 AHU02 INTAKE	G	A02E	1200		600	600	0.83	21	67	IL	7	15	28	41	55	55	48	32
8	SA08 AHU02 SUPPLY	G	A02E	900		600	600	0.83	19	54	IL	6	11	22	31	49	43	36	24
9	SA09 AHU03 SUPPLY	GJ	A02E	1200		700	400	0.94	27	53	IL	9	16	25	37	49	40	33	20
10	SA10 AHU03 EXTRACT	GJ	A02E	1200		700	400	0.94	27	53	IL	9	16	25	37	49	40	33	20
11	SA11 AHU03 INTAKE	GJ	A02E	1200		700	400	0.94	27	53	IL	9	16	25	37	49	40	33	20
12	SA12 AHU03 EXHAUST	GJ	A02E	1200		700	400	0.94	27	53	IL	9	16	25	37	49	40	33	20
13	SA13 AHU04 SUPPLY	G	A02E	2100		700	400	0.708	24	92	IL	12	23	38	55	55	55	52	31
14	SA14 AHU04 EXTRACT	G	A02E	2100		700	400	0.708	24	92	IL	12	23	38	55	55	55	52	31
15	SA15 AHU04 INTAKE	G	A02E	1200		700	400	0.708	20	58	IL	8	16	26	39	55	47	36	22
16	SA16 AHU04 EXHAUST	G	A02E	1200		700	400	0.708	20	58	IL	8	16	26	39	55	47	36	22
17	SA17 TEF01 EXTRACT	GE	A18D	900	150	250	200	0.08	17	15	IL	4	9	16	28	48	42	36	22
18	SA18 TEF01 EXHAUST	GE	A18D	900	150	250	200	0.08	17	15	IL	4	9	16	28	48	42	36	22

NOTES:

LABEL WITH ITEM NO. & SYSTEM REF.

IL = STATIC INSERTION LOSS (dB)

ILA.

SUFFIX M INDICATES ATTENUATORS TO BE SUPPLIED WITH ACOUSTIC MEDIA LINED WITH MELINEX.